

DEPARTMENT	SOLICITATION TYPE	PROJECT NAME
Employment Development Department (EDD)	Invitation for Bid (IFB) No. 128797	Alarm System Dialer and Panel Upgrade Installation Services for 2 Northern California CUIAB Facilities
SERVICES REQUESTED	TOPIC	PUBLICATION DATE
Non-IT Services	Question & Answer Set	August 26, 2026

ATTENTION: ALL PROSPECTIVE BIDDERS:

Following are the questions related to the above-referenced IFB. All prospective respondents are cautioned to carefully review the following list prior to submitting a proposal as it contains important clarifications not previously contained in the IFB.

#	QUESTIONS	ANSWERS
1	Are the existing panels datalocked or installer-code protected, and are those codes on record?	Yes. The current vendor should have these codes.
2	Is EDD intending existing field devices to be in scope, or would conditions outside the specified equipment be handled separately?	The scope does not include repair or replacement of any detection devices. Testing and repair of these devices would be handled through a separate, existing contract.
3	Is there currently an alarm monitoring contract in place?	Yes, although we cannot disclose the details of the current contract.
4	Is there any service currently required?	None are known, but any repairs would be facilitated through the existing monitoring and maintenance contract.
5	Would a DMP XR150 alarm panel be acceptable in place of the Radionix brand panel?	Exhibit A-1, Specifications, Section III. A. incitate "The Contractor shall program and install a Radionix B8512G (or similar) intrusion control panel." As long as the panel is similar to Radionix B8512G then it will suffice.
6	Is there an opportunity to inspect the site prior to bidding?	No, a site inspection will not be available.
7	Since a prior solicitation was done for this, are vendors who previously bid required to submit a completely new bid package or will prior submissions carry forward?	Even if you bid in the prior solicitation, you will still need to submit a complete bid package by the due date to be considered. Most of the forms are the same as the prior solicitation. If you are planning on submitting a bid for this round, please ensure you are submitting the most updated forms to ensure a responsive bid.