

PANELBOARD			LA			SCHEDULE		
VOLTAGE: 208Y/120 V MAINS 250A MAIN BREAKER			TOTAL LOAD: 50.5 KVA			FAULT DUTY: 22,000 AIC		
BUS SIZE: 225 A			TOTAL LOAD: 50.5 KVA			FAULT DUTY: 22,000 AIC		
NO	SERVICES	LOAD (kVA)	TRIP	PHASE	FAULT DUTY: 22,000 AIC	LOAD (kVA)	TRIP	NO
1	CRIMINAL INVEST	1.0	20	1	1	0.8	20	2
3	CONF 1224	1.0	20	1	1	0.8	20	4
4	TOILETS	1.0	20	1	1	0.8	20	6
5	TOILETS	1.0	20	1	1	0.8	20	8
7	PHYSICAL TRNG	1.2	20	1	1	0.6	20	10
9	CLERICAL 1215	1.0	20	1	1	0.0	20	12
11	OFFICE 1214	0.6	20	1	1	0.2	20	14
13	OFFICE 1234	1.2	20	1	1	0.0	20	16
15	SPARE	1.0	20	1	1	0.2	20	18
17	TOILETS 1223	1.2	20	1	1	0.2	20	20
19	CLERICAL 1215	1.0	20	1	1	0.2	20	22
21	TRAINING CTR	1.2	20	1	1	0.2	20	24
23	TRAINING CTR	1.2	20	1	1	0.0	20	26
25	OFFICE 1239	1.2	20	1	1	0.2	20	28
27	PAINT 1236	0.6	20	1	1	0.2	20	30
29	CLERICAL 1215	1.0	20	1	1	0.2	20	32
31	OFFICE 1238	0.8	20	1	1	0.2	20	34
33	OFFICE 1072	1.2	20	1	1	0.2	20	36
35	HEARING ROOM	1.8	20	1	1	0.8	20	38
37	DOWN IS 1226	1.4	20	1	1	0.2	20	40
39	DOWN IS 1001	0.6	20	1	1	0.4	20	42
41	WH-2	0.2	20	1	1	0.0	20	44
43	WH-2	0.2	20	1	1	0.0	20	46
45	WH-2	0.2	20	1	1	0.0	20	48
47	WH-1	0.1	20	1	1	0.7	20	50
49	DOWN IS 1001	1.1	20	1	1	0.2	20	52
51	STOVE BRKRM 1213	0.1	20	1	1	0.2	20	54
53	WH-2	0.1	20	1	1	0.2	20	56
55	WH-2	0.1	20	1	1	0.2	20	58
57	WH-2	0.1	20	1	1	0.2	20	60
59	WH-2	0.1	20	1	1	0.2	20	62
61	WH-2	0.1	20	1	1	0.2	20	64
63	WH-2	0.1	20	1	1	0.2	20	66
65	WH-2	0.1	20	1	1	0.2	20	68
67	WH-2	0.1	20	1	1	0.2	20	70
69	WH-2	0.1	20	1	1	0.2	20	72
71	WH-2	0.1	20	1	1	0.2	20	74
73	WH-2	0.1	20	1	1	0.2	20	76
75	WH-2	0.1	20	1	1	0.2	20	78
77	WH-2	0.1	20	1	1	0.2	20	80
79	WH-2	0.1	20	1	1	0.2	20	82
81	WH-2	0.1	20	1	1	0.2	20	84
83	WH-2	0.1	20	1	1	0.2	20	86

PANELBOARD			LD			SCHEDULE		
VOLTAGE: 208Y/120 V MAINS 100A MAIN BREAKER			TOTAL LOAD: 16.3 KVA			FAULT DUTY: 22,000 AIC		
BUS SIZE: 100 A			TOTAL LOAD: 16.3 KVA			FAULT DUTY: 22,000 AIC		
NO	SERVICES	LOAD (kVA)	TRIP	PHASE	FAULT DUTY: 22,000 AIC	LOAD (kVA)	TRIP	NO
1	EF-36/GUIN-DI	0.3	20	1	1	0.8	20	2
3	EF-39	0.6	20	1	1	0.6	20	4
5	CHASE 1427	0.8	20	1	1	0.6	20	6
7	FIRE RISER 1426	0.8	20	1	1	0.6	20	8
9	CHASE 1424/1425	1.2	20	1	1	0.2	20	10
11	MULTIPURPOSE 1421	0.6	20	1	1	0.2	20	12
13	MULTIPURPOSE 1421	0.6	20	1	1	0.2	20	14
15	AREA D MEZZANINE	0.8	20	1	1	0.2	20	16
17	CONTROL 2408	1.2	20	1	1	0.4	20	18
19	AREA D MEZZANINE	0.6	20	1	1	0.4	20	20
21	VIDEO PHONES DAYROOMS	1.2	20	1	1	0.2	20	22
23	VIDEO PHONES DAYROOMS	1.2	20	1	1	0.2	20	24
25	VIDEO PHONES DAYROOMS	1.2	20	1	1	0.2	20	26
27	SPARE	0.1	20	1	1	0.2	20	28
29	SPARE	0.1	20	1	1	0.2	20	30
31	SPARE	0.1	20	1	1	0.2	20	32
33	SPARE	0.1	20	1	1	0.2	20	34
35	SPARE	0.1	20	1	1	0.2	20	36
37	SPARE	0.1	20	1	1	0.2	20	38
39	SPARE	0.1	20	1	1	0.2	20	40
41	SPARE	0.1	20	1	1	0.2	20	42

PANELBOARD			LK			SCHEDULE		
VOLTAGE: 208Y/120 V MAINS 400A MAIN BREAKER			TOTAL LOAD: 111.2 KVA			FAULT DUTY: 22,000 AIC		
BUS SIZE: 400 A			TOTAL LOAD: 111.2 KVA			FAULT DUTY: 22,000 AIC		
NO	SERVICES	LOAD (kVA)	TRIP	PHASE	FAULT DUTY: 22,000 AIC	LOAD (kVA)	TRIP	NO
1	TRAY CABINET	0.4	20	1	1	0.2	20	2
3	SPARE	0.1	20	1	1	0.2	20	4
5	SPARE	0.1	20	1	1	0.2	20	6
7	ROLL-IN REFRIG	1.4	20	1	1	0.2	20	8
9	SLIDER	1.2	20	1	1	0.2	20	10
11	SLIDER	1.2	20	1	1	0.2	20	12
13	WARMING CABINET	2.2	20	1	1	0.2	20	14
15	FLOOR MIXER	2.2	20	1	1	0.2	20	16
17	20 QT MIXER	1.5	20	1	1	0.2	20	18
19	20 QT MIXER	1.5	20	1	1	0.2	20	20
21	VEG SLICER	1.2	20	1	1	0.2	20	22
23	VEG SLICER	1.2	20	1	1	0.2	20	24
25	VEG SLICER	1.2	20	1	1	0.2	20	26
27	VEG SLICER	1.2	20	1	1	0.2	20	28
29	VEG SLICER	1.2	20	1	1	0.2	20	30
31	BEVERAGE DISPENSER	1.2	20	1	1	0.2	20	32
33	BEVERAGE DISPENSER	1.2	20	1	1	0.2	20	34
35	BEVERAGE DISPENSER	1.2	20	1	1	0.2	20	36
37	BEVERAGE DISPENSER	1.2	20	1	1	0.2	20	38
39	BEVERAGE DISPENSER	1.2	20	1	1	0.2	20	40
41	KITCHEN OFFICE	0.6	20	1	1	0.2	20	42
43	KITCHEN OFFICE	0.6	20	1	1	0.2	20	44
45	KITCHEN OFFICE	0.6	20	1	1	0.2	20	46
47	KITCHEN OFFICE	0.6	20	1	1	0.2	20	48
49	KITCHEN OFFICE	0.6	20	1	1	0.2	20	50
51	SPARE	0.1	20	1	1	0.2	20	52
53	SPARE	0.1	20	1	1	0.2	20	54
55	SPARE	0.1	20	1	1	0.2	20	56
57	SPARE	0.1	20	1	1	0.2	20	58
59	SPARE	0.1	20	1	1	0.2	20	60
61	SPARE	0.1	20	1	1	0.2	20	62
63	SPARE	0.1	20	1	1	0.2	20	64
65	SPARE	0.1	20	1	1	0.2	20	66
67	SPARE	0.1	20	1	1	0.2	20	68
69	SPARE	0.1	20	1	1	0.2	20	70
71	SPARE	0.1	20	1	1	0.2	20	72
73	SPARE	0.1	20	1	1	0.2	20	74
75	SPARE	0.1	20	1	1	0.2	20	76
77	SPARE	0.1	20	1	1	0.2	20	78
79	SPARE	0.1	20	1	1	0.2	20	80
81	SPARE	0.1	20	1	1	0.2	20	82
83	SPARE	0.1	20	1	1	0.2	20	84

PANELBOARD			LAA			SCHEDULE					
VOLTAGE: 208Y/120 V MAINS 150A MAIN BREAKER			TOTAL LOAD: 36.5 KVA			MOUNTING: SURFACE			REMARKS		
BUS SIZE: 150 A			TOTAL LOAD: 36.5 KVA			FAULT DUTY: 22,000 AIC			-----		
NO	SERVICES	LOAD (kVA)	TRIP	PHASE			LOAD (kVA)	TRIP	SERVICES	NO	
				F	A	B					
1	EVIDENCE GARAGE	0.6	20	1	1	1	0.8	20	MISC EQUIP	2	
3	EVIDENCE GARAGE	0.4	20	1	1	1	20	12	WORKROOM	4	
5	PHYSICAL TRNG	1.2	20	1	1	1	20	12	WORKROOM CUPBR	6	
7	PHYSICAL TRNG	1.2	20	1	1	1	20	12	WORKROOM CUPBR	8	
9	CLERICAL INVEST	1.0	20	1	1	1	20	12	CLERICAL 1219	10	
11	CRIMINAL INVEST	1.2	20	1	1	1	20	12	CLERICAL 1239	12	
13	CRIMINAL INVEST	1.2	20	1	1	1	20	12	CLERICAL 1239	14	
15	CRIMINAL INVEST	1.2	20	1	1	1	20	12	LIBRARY 1201	16	
17	CRIMINAL INVEST	1.2	20	1	1	1	20	12	TOILETS/HALL 1244	18	
19	CRIMINAL INVEST	1.2	20	1	1	1	20	12	SPARE	20	
21	CRIMINAL INVEST	1.2	20	1	1	1	20	12	SPARE	22	
23	INTERVIEW 1204	1.0	20	1	1	1	20	10	1242	24	
25	TARE/INTERVIEW 1206	1.2	20	1	1	1	20	10	1243	26	
27	CRIMINAL INVEST WALL	0.6	20	1	1	1	20	12	1207/1210	28	
29	CRIMINAL INVEST WALL	1.2	20	1	1	1	20	12	BREAK-ARM 1219 CTR	30	
31	CRIMINAL INVEST WALL	1.2	20	1	1	1	20	12	BREAK-ARM 1219 CTR	32	
33	CRIMINAL INVEST WALL	1.2	20	1	1	1	20	12	BREAK-ARM 1219 CTR	34	
35	CRIMINAL INVEST WALL	0.8	20	1	1	1	20	12	BREAK-ARM 1219 CTR	36	
37	OFFICE 1255	0.8	20	1	1	1	20	0.6	BREAK-ARM 1219 CTR	38	
39	SPARE	1.1	20	1	1	1	20	0.4	BREAK-ARM 1219 CTR	40	
41	SPARE	1.1	20	1	1	1	20	0.8	EF-A4/A5	42	
43	SPARE	1.1	20	1	1	1	20	0.8	EF-A4/A5	44	
45	SPARE	1.1	20	1	1	1	20	0.4	EF-A4/A5	46	
47	SPARE	1.1	20	1	1	1	20	0.4	EF-A4/A5	48	
49	SPARE	1.1	20	1	1	1	20	0.4	SPARE	50	
51	SPARE	1.1	20	1	1	1	20	0.8	SPARE	52	
53	SPARE	1.1	20	1	1	1	20	0.8	SPARE	54	
55	SPARE	1.1	20	1	1	1	20	0.8	SPARE	56	
57	SPARE	1.1	20	1	1	1	20	0.8	SPARE	58	
59	SPARE	1.1	20	1	1	1	20	0.8	SPARE	60	
61	SPARE	1.1	20	1	1	1	20	0.8	SPARE	62	
63	SPARE	1.1	20	1	1	1	20	0.8	SPARE	64	
65	SPARE	1.1	20	1	1	1	20	0.8	SPARE	66	
67	SPARE	1.1	20	1	1	1	20	0.8	SPARE	68	
69	SPARE	1.1	20	1	1	1	20	0.8	SPARE	70	
71	SPARE	1.1	20	1	1	1	20	0.8	SPARE	72	
73	SPARE	1.1	20	1	1	1	20	0.8	SPARE	74	
75	SPARE	1.1	20	1	1	1	20	0.8	SPARE	76	
77	SPARE	1.1	20	1	1	1	20	0.8	SPARE	78	
79	SPARE	1.1	20	1	1	1	20	0.8	SPARE	80	
81	SPARE	1.1	20	1	1	1	20	0.8	SPARE	82	
83	SPARE	1.1	20	1	1	1	20	0.8	SPARE	84	