



Orange Water and Sewer Authority

Our community's trusted partner for clean water and environmental protection

ADDENDA

ADDENDUM NUMBER 02

DATE: 6-25-2026

PROJECT: Sykes St. Paving Restoration

OWASA CIP NUMBER: 275-20

OWNER: ORANGE WATER AND SEWER AUTHORITY

TO: ALL SUBMITTERS

This Addendum is to provide answers to questions submitted by Contractors concerning the Sykes St. Paving Restoration.

Addenda #02 consists of 1 page:

Questions:

1. Do you happen to know the specification for the 24" by 12' stop bar replacement? I can't find whether it calls for thermoplastic or paint or what TOCH's requirement is.

Answer: The 24" x 12' stop bar replacement shall be white thermoplastic pavement marking material installed in accordance with Town of Chapel Hill and applicable NCDOT standards.



Orange Water & Sewer Authority

Addenda
Sykes St. Paving Restoration