AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

1. CONTRACT ID CODE	PAGE	OF	PAGES
	1		2

2. AMENDMENT/MODIFICATION NUMBER	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQUISITION NUMBER	5. PROJECT NUMBER *(If applicable)*
0004	06/26/2026		

6. ISSUED BY CODE R20

Bureau of Reclamation
Mid-Pacific Region
Regional Office
Division of Acquisition Services
2800 Cottage Way, Room E-1815
Sacramento CA 95825-1898

7.ADMINISTERED BY *(If other than Item 6)* CODE

8. NAME AND ADDRESS OF CONTRACTOR *(Number, street, county, State and ZIP Code)*

CODE | FACILITY CODE

(X) 9A. AMENDMENT OF SOLICITATION NUMBER
140R2026Q0079

☒ 9B. DATED *(SEE ITEM 11)*
06/02/2026

☐ 10A. MODIFICATION OF CONTRACT/ORDER NUMBER

10B. DATED *(SEE ITEM 13)*

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended. ☒ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA *(If required)*

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NUMBER AS DESCRIBED IN ITEM 14.

CHECK ONE	
☐	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: *(Specify authority)* THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NUMBER IN ITEM 10A.
☐	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES *(such as changes in paying office, appropriation data, etc.)* SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
☐	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
☐	D. OTHER *(Specify type of modification and authority)*

E. IMPORTANT: Contractor ☐ is not ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (*Organized by UCF section headings, including solicitation/contract subject matter where feasible.)*

See continuation page

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER *(Type or print)*		16A. NAME AND TITLE OF CONTRACTING OFFICER *(Type or print)*	
		Rosana Yousefgoarji	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
(Signature of person authorized to sign)		*(Signature of Contracting Officer)*	

Previous edition unusable

STANDARD FORM 30 (REV. 11/2016)
Prescribed by GSA FAR (48 CFR) 53.243

NAME OF OFFEROR OR CONTRACTOR

ITEM NO. (A)	SUPPLIES/SERVICES (B)	QUANTITY (C)	UNIT (D)	UNIT PRICE (E)	AMOUNT (F)
	The Solicitation cited in block 9A above, Lake Berryessa East Side Road Fence Repairs is hereby amended. Purpose: The purpose of this amendment is to incorporate the attached Questions/Answers. The date and time for receipt of offers is hereby UNCHANGED and remains July 2, 2026, at 12:00 p.m. The offeror must acknowledge this amendment by submitting a signed copy of this SF30 along with their proposal.				

Title: Lake Berryessa East Side Road Fence Repairs
Solicitation No.: 140R2026Q0079
Amendment No. 0004

Contractor's Pre-bid Questions

Question 1. The new amendment requests all wooden posts to be removed is there a storage/reclamation facility these should be delivered to? Or, will these need to be disposed of off site?

Response 1: They would need to be disposed of offsite.

Question 2. I can have a roll off box service truck for debris and waste- will it need to be at staging area, or can it be closer to the fence line?

Response 2: Any truck or container for debris, as well as all other equipment, must be staged at Eticuera. Staging is not allowed along the fence line due to NEPA requirements.

Questions 3. The water for the cement mixing- will it need to be hauled in from a bulk water supplier? Or can we fill up our tanks from utilities near the lake? Or we have submersible pumps we can draw water from the lake.

Response 3: The contractor can use pumps to draw water from the lake. There are no utilities available in that area.

Questions 4. Hot work to cut cattle panels at water crossings. Can we cut the panels with a grinder/torch? If not, we will have to use bolt cutters. Also, water gap connections and other h pipe connections may need some hot work done as well - a cutting torch will be needed to cut a hole in pipes. If no hot work allowed, we can drill-it will however take longer.

Response 4: These are allowed only if current fire restrictions (e.g., Red Flag Warnings or agency fire bans) do not prohibit it, and all required hot-work safety measures and permits are followed. This includes having a fire watch, controlling sparks, and clearing combustibles. If these conditions cannot be met, cold-cutting methods (bolt cutters, drilling, etc.) must be used.

Questions 5. Charging of portable tools - are there outlets at visitor center to charge batteries? if not we have generators that are portable.

Response 5: There are no outlets available. A generator may be used at the staging area.