AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

1. CONTRACT ID CODE	PAGE	OF	PAGES
	1		3

2. AMENDMENT/MODIFICATION NUMBER	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQUISITION NUMBER	5. PROJECT NUMBER *(If applicable)*
0002	06/16/2026		

6. ISSUED BY CODE WAD-NWS

WAD-NWS
7600 SAND POINT WAY NE BLDG 1
SEATTLE WA 98115

7.ADMINISTERED BY *(If other than Item 6)* CODE

8. NAME AND ADDRESS OF CONTRACTOR *(Number, street, county, State and ZIP Code)*

CODE FACILITY CODE

(X) 9A. AMENDMENT OF SOLICITATION NUMBER
1305M326Q0245

[X] 9B. DATED *(SEE ITEM 11)*
06/16/2026

10A. MODIFICATION OF CONTRACT/ORDER NUMBER

[ ]

10B. DATED *(SEE ITEM 13)*

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

[X] The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers [X] is extended. [ ] is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA *(If required)*

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NUMBER AS DESCRIBED IN ITEM 14.

CHECK ONE

[ ] A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: *(Specify authority)* THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NUMBER IN ITEM 10A.

[ ] B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES *(such as changes in paying office, appropriation data, etc.)* SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).

[ ] C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:

[ ] D. OTHER *(Specify type of modification and authority)*

E. IMPORTANT: Contractor [ ] is not [ ] is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (*Organized by UCF section headings, including solicitation/contract subject matter where feasible.)*

See continuation page

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER *(Type or print)*		16A. NAME AND TITLE OF CONTRACTING OFFICER *(Type or print)*	
		HANNAH HARTMAN	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
(Signature of person authorized to sign)		*(Signature of Contracting Officer)*	

NAME OF OFFEROR OR CONTRACTOR

ITEM NO. (A)	SUPPLIES/SERVICES (B)	QUANTITY (C)	UNIT (D)	UNIT PRICE (E)	AMOUNT (F)
	This amendment 0002 is issued to answer questions recieved in response to the RFQ, and extend the deadline for quote submission to 6 July 2026 at 1400 PST. The reason for extension is because some questions are still waiting a response from a technical point of contact. Period of Performance: 07/15/2026 to 11/12/2026				

RFQ Amendment 1305M326Q0245 0002

No.	Your Question	Government Response
1	DO YOU WANT THE NEW BUILDING TO HAVE ITS OWN FLOOR OR DO YOU WANT IT BUILT ON THE CONCRETE PAD THAT IS THERE NOW?	The building will need to have its own floor installed. This structure should not be permanantly set.
2	IS THERE A CERTIAN COLOR YOU WANT THE BUILDING TO BE?	Neutral colors of tan/brown/whites are preferred
3	IS THE GENERATOR GOING TO BE MOVED TO THE NEW PAD OR IS THE NEW PAD GOING UNDER THE GENERATOR NOW?	The generator will need to be reinstalled in its current location after work has been completed.
4	IF THE GENERATOR NEEDS TO BE MOVED, WHO WILL BE RESPONSIBLE FOR MOVING IT?	The generator will be disconnected by NWS personnel. It will be the contractors responsibility to move it and put it back in the same location. NWS will reconnect the generator when the project is finished.
5	ARE WE USING ATTACHEMENT 1 FOR ANY INFORMATION ON THE PROJECT SINCE IT HAS BEEN REDACTED?	The redaction is only for points of contact that will be relaeased once contract is awarded. The rest of the SOW is available.
6	Is the contractor responsible for disconnecting and physically relocating the existing generator during construction?	The generator will be disconnected by NWS personnel. If it needs to be moved it will be the contractors responsibility to move it and put it back in the same location. NWS will reconnect the generator when the project is finished.
7	Will NOAA/NWS personnel perform all generator and transfer switch reconnections?	All generator and transfer switch reconnections will be done by NWS personnel.
8	Is temporary power required during construction or during the transition period between removal of the existing shelter and commissioning of the new shelter?	No, The site will be turned down and completely offline during this project
9	Will NOAA/NWS personnel remove and reinstall all communications equipment associated with the transmitter site?	Yes, all comms equipment will be handled by the NWS
10	Will NOAA/NWS personnel disconnect and reconnect all Heliax antenna cables, grounding conductors, telemetry equipment, and communication systems?	Yes, all equipment will be reinstalled by the NWS
11	What outage window is available for transmitter shutdown and cutover activities?	The NWS will aim for a Monday turn down, and would like to be operational by Friday of the same week.
12	Please clarify which existing equipment will be removed and reinstalled by NOAA/NWS personnel and which equipment are the responsibility of the contractor. Specifically, please identify responsibility for the electrical panel, communications equipment, Heliax antenna cables, grounding components, and associated conduit systems.	electrical panel - contractor, communications equipment - NWS, Heliax antenna cables - NWS, grounding components to equipment - NWS, and associated conduit systems - NWS. To clairify, all equipment side connections will be handled by the NWS.
13	Are prefabricated communications shelters acceptable for this project?	Yes
14	Are there any preferred or previously approved shelter manufacturers?	No
15	Is a Florida-engineered shelter required for compliance with applicable codes and wind-load requirements?	yes
16	Has the Government conducted any asbestos, lead-based paint, or hazardous materials surveys for the existing structure?	No, but site was installed in May of 1996, so there should be no hazardous materials present