AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

1. CONTRACT ID CODE	PAGE	OF	PAGES
J	1		6

2. AMENDMENT/MODIFICATION NUMBER	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQUISITION NUMBER	5. PROJECT NUMBER *(If applicable)*
0003	25 JUN 2026		562346

6. ISSUED BY	CODE	7. ADMINISTERED BY *(If other than Item 6)*	CODE
W912DS			

W2SD ENDIST NEW YORK
KO CONTRACTING DIVISION, 26 FEDERAL PLAZA ROOM 16 300
NEW YORK, NY 10278-0004
UNITED STATES
MOHENDA SURAGE, EMAIL: MOHENDA.R.SURAGE@USACE.ARMY.MIL
TELEPHONE: 917-940-8013

SCD: PAS:

8. NAME AND ADDRESS OF CONTRACTOR *(Number, street, county, State and ZIP Code)*

CODE | FACILITY CODE

(X)

☒ 9A. AMENDMENT OF SOLICITATION NUMBER
W912DS26BA020

9B. DATED *(SEE ITEM 11)*
29 MAY 2026

☐ 10A. MODIFICATION OF CONTRACT/ORDER NUMBER

10B. DATED *(SEE ITEM 13)*

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended. ☒ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
(a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;
or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER.
If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA *(If required)*

SEE SECTION G - CONTRACT ADMINISTRATION DATA

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NUMBER AS DESCRIBED IN ITEM 14.

CHECK ONE	
☐	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: *(Specify authority)* THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NUMBER IN ITEM 10A.
☐	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES *(such as changes in paying office, appropriation data, etc.)* SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
☐	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
☐	D. OTHER *(Specify type of modification and authority)*

E. IMPORTANT: Contractor ☐ is not ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (*Organized by UCF section headings, including solicitation/contract subject matter where feasible.)*

The purpose of this amendment is to:
Answer questions from prospective bidders for informational purposes only
The bid opening date remains 29-June-2026 at 2:00 P.M. EST

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER *(Type or print)*		16A. NAME AND TITLE OF CONTRACTING OFFICER *(Type or print)*	
		NICHOLAS EMANUEL	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
(Signature of person authorized to sign)		*(Signature of Contracting Officer)*	26 JUN 2026

Previous edition unusable

STANDARD FORM 30 (REV. 11/2016)
Prescribed by GSA FAR (48 CFR) 53.243

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

Section 00 72 00 - General Conditions

Miscellaneous text in this section has been added to:

Joint Base McGuire-Dix-Lakehurst, NJ

Hot Cargo Loading Area

W912DS26BA020

Amendment 0003

AMENDMENT 0003 to DRAWINGS and SPECIFICATIONS for Hot Cargo Loading Area, at JBMDL NJ.

TO OFFERORS

The following changes shall be made to the drawings and specifications.

DRAWINGS

1. The following DRAWINGS have been REVISED but NOT REISSUED:

   - *None*

2. The following DRAWINGS have been REVISED and REISSUED:

   - *None*

3. The following DRAWINGS have been ADDED:

   - *None*

4. The following DRAWINGS have been DELETED:

- *None*

SPECIFICATIONS

1. The following SPECIFICATION SECTIONS have been ADDED and are provided in their entirety herein:

- *None*

2. The following SPECIFICATIONS SECTIONS have been DELETED in their entirety:

- ***None***

3. The following SPECIFICATIONS SECTIONS have been REVISED and REISSUED:

- ***None***

4. The following SPECIFICATIONS have been REVISED but NOT REISSUED:

- ***None***

PROPOSER'S QUESTIONS AND GOVERNMENT REPLY

Questions that may be of general interest to all Offerors and/or the Government and that are not readily answered by the proceeding changes will appear below. These questions may have been paraphrased or altered to represent several questions regarding the same subject and/or simply revised to clarify and simplify the question(s). Questions and answers are issued to the Offerors "for information only" and do not revise the solicitation, plans or specifications.

1. Spec Section 32 31 13.53 Is the fencing to be all galvanized Pipe and fence fabric or Brown coated as per base standards? - ***RESPONSE: Galvanized fence is sufficient.***

2. Spec Section 32 31 13.53 Is the 40' W Cantilever gate a duel track since the opening is over 30" W? - ***RESPONSE: please follow the manufacturer's recommendation for the size of the gate required***.

3. Section 01 57 -19 -1.5.4 Environmental Manager -Can the site super act as Env Manager? ***RESPONSE: The specification allows collateral position; however, the individual must meet the specified qualifications of paragraph 1.5.4.***

4. SSHO and QC manager can be the same person? ***RESPONSE: The Quality Control (QC) Manager can not have any other duties than managing and implementing the QC program as required by specification section 01 45 00, paragraph 1.7.2.1, and have the qualifications required by paragraph 1.7.2.2. However, they can be designated by the Corporate Safety Official as the Site Safety and Health Officer. They must meet the qualifications specified for the SSHO as well as the QC Manager.***

5. Section 01 30 00 - 1.8 -Superintendent Qualifications- how many superintendents are required on a daily basis? ***RESPONSE: Specification section 01 30 00, paragraph 1.9 specifies how many superintendents are required on the project. The number of superintendents required depends on the amount of work that the Prime contractor subcontracts, based on the contract amount.***

6. Can the Bids due date be extended? ***RESPONSE: Unfortunately bid due date extension is not possible.***

7. The note #3 AC on GC -201 -" ALL EXCAVATED CONTAMINATED MATERIAL SHALL BE DISPOSED OF AT THE CONTAMINATED SOIL DISPOSAL LOCATION NEAR THE JBMDL FUEL FARM". The note #3 on in the RFP documents call for off-site disposal. Which one should we follow? ***RESPONSE: please refer to reply #3 in amendment #2. The referenced note is hereby deleted by this amendment.***