Questions & Answers for 70Z03326Q2019000003

Updated: 02 June 2026

Can the Government confirm the required submission method and the specific email address for the final quote package?

- The requirements for the submission of quotes is specifically listed in the Description section of SAM.gov solicitation 70Z03326Q2019000003.

Is there a formal deadline for submitting questions regarding this RFQ?

- No further questions regarding this solicitation will be answered after 3:00 PM PDT on 07/03/2026 as per the solicitation description.

Is a site visit or field verification available prior to the quote submission deadline?

- Site visit dates and arrangements is listed in the Description section of SAM.gov solicitation 70Z03326Q2019000003.

The SOW states all work shall be performed by licensed contractors registered in SAM.gov. Does this requirement apply to all flooring subcontractors, or only to the prime offeror?

- All work must be performed by licensed contractors registered in SAM.gov. This applies to the prime contractor; subcontractors must comply with applicable registration and licensing requirements.

Does FAR 52.219-14, Limitations on Subcontracting, apply to this acquisition?

- As this contract amount is not expected to exceed the simplified acquisition threshold, FAR 52.219-14 does not apply.

If FAR 52.219-14 applies, should this be treated as a service contract or as specialty trade construction under NAICS 238330 for subcontracting limitations?

- Not applicable; see answer to the previous question.

Is “Carpet Layer” the expected wage classification for installation labor, or should offerors request a conformance for additional classifications?

- Wage Determination No. 2015-5535 is provided in the Attachments/Links section of SAM.gov solicitation 70Z03326Q2019000003 to determine the applicable wages for all required job classifications as part of the proposed contract.

Can the Government provide the specified carpet tile manufacturer, style, color, backing, and installation pattern?

- TAS Contract Local Legend Crossroads Way 15 oz Commercial Carpet Tile or equal: See attached product data sheet
- Salient Characteristics:
    - Construction: Tufted Pattern Loop, 15 oz nylon.

    - Performance: Solution-dyed nylon with 10 Year Stain Resistance Limited Warranty.
    - Backing: Ultra Set Matrix or equal.
    - Size: 24'' x 24'' tiles.
    - Warranties: Lifetime wear, static, colorfastness, and edge ravel protection.
- Quarter Turn installation pattern
- Color to be selected as part of the submittal/sample process

Will the Government provide a floor plan identifying the exact areas included in the 7,422 SF quantity?

- An FDCC floor plan is provided in the Attachments/Links section of SAM.gov solicitation 70Z03326Q2019000003.

Is the 7,422 SF quantity inclusive of the waste factor, or should offerors account for additional material waste in their pricing?

- 7,422 square feet approximates the required coverage area and is not a definitive material requirement. Offerors should account for appropriate material waste in their pricing.

To confirm, is furniture removal and replacement fully excluded from this scope and handled by a separate vendor?

- Yes, furniture removal and replacement is handled by a separate vendor and is excluded from this scope.

Will the flooring contractor have access to the full open floor area immediately following furniture removal?

- Yes, carpet replacement will occur in an open floor area following furniture removal by the separate vendor.

Are after-hours or weekend work windows available if necessary to coordinate with the furniture vendor's schedule?

- Work is to be performed during normal working hours (M-F 0600-1700). After-hours work may be approved by the Contracting Officer if necessary.

Are specific loading dock rules, elevator access regulations, badging requirements, or disposal requirements available at this time?

- Disposal must be coordinated according to GSA building requirements, using the Jackson Federal Building 3rd floor loading dock. Additional access and badging requirements will be provided prior to project start.

Are contractor personnel required to complete specific access forms or background checks to work in the Jackson Federal Building?

- Access and badging requirements will be provided prior to project start. Contractors should be prepared to comply with federal building security procedures.

Are product data sheets required to be submitted with the quote, or are they due after the award?

- Product data sheets are required as a post-award submittal, not with the quote.

Is a formal safety plan required with the quote submission or after the award?

- A safety plan is required as a post-award submittal, not with the quote.