PANEL A

125 AMP BUS
120/240 VOLTS
SURFACE MOUNTED

LOAD SERVED	CKT. NO.		CKT. NO.		LOAD SERVED
A/C COMBO UNIT	A	1	2	A	OFFICE RECEPTS
A/C COMBO UNIT	B			B	SPARE
A/C COMBO UNIT	A	3	4	A	SPARE
A/C COMBO UNIT	B			B	OFFICE RECEPTS
SPARE	A	5	6	A	OFFICE RECEPT
SPARE	B			B	HALLWAY HEAT
SPARE	A	7	8	A	HALLWAY HEAT
SPARE	B			B	OFFICE RECEPT
SPARE	A	9	10	A	OFFICE LIGHTS
SPARE	B			B	EM. LIGHT & HALLWAY LIGHT
SPARE	A	11	12	A	OFFICE LIGHTS
SPARE	B			B	SPARE
SPARE	A	13	14	A	SPARE
SPARE	B			B	OUTSIDE LIGHT
EXIT LIGHT	A	15	16	A	SPARE
SPARE	B			B	SPARE

PANEL B

125 AMP BUS
120/240 VOLTS
SURFACE MOUNTED

LOAD SERVED	CKT. NO.		CKT. NO.		LOAD SERVED
A/C COMBO UNIT	A	1	2	A	OFFICE RECEPTS
A/C COMBO UNIT	B			B	OFFICE RECEPTS
A/C COMBO UNIT	A	3	4	A	OFFICE RECEPT
A/C COMBO UNIT	B			B	SPARE
SPARE	A	5	6	A	OFFICE RECEPT
SPARE	B			B	
SPARE	A	7	8	A	OFFICE RECEPT
SPARE	B			B	
SPARE	A	9	10	A	HALLWAY RECEPT
SPARE	B			B	SPARE
SPARE	A	11	12	A	OFFICE LIGHTS
SPARE	B			B	SPARE
SPARE	A	13	14	A	OFFICE LIGHTS
SPARE	B			B	SPARE
SPARE	A	15	16	A	SPARE
SPARE	B			B	SPARE

PANEL C

125 AMP BUS
120/240 VOLTS
SURFACE MOUNTED

LOAD SERVED	CKT. NO.		CKT. NO.		LOAD SERVED
A/C COMBO UNIT	A	1	2	A	OFFICE RECEPTS
A/C COMBO UNIT	B			B	OFFICE RECEPTS
A/C COMBO UNIT	A	3	4	A	OFFICE RECEPT
A/C COMBO UNIT	B			B	SPARE
SPARE	A	5	6	A	OFFICE RECEPT
SPARE	B			B	
SPARE	A	7	8	A	OFFICE RECEPT
SPARE	B			B	
SPARE	A	9	10	A	OFFICE LIGHTS
SPARE	B			B	SPARE
SPARE	A	11	12	A	SPARE
SPARE	B			B	OFFICE LIGHTS
SPARE	A	13	14	A	HALLWAY LIGHT
SPARE	B			B	SPARE
SPARE	A	15	16	A	SPARE
SPARE	B			B	SPARE

PANEL D

125 AMP BUS
120/240 VOLTS
SURFACE MOUNTED

LOAD SERVED	CKT. NO.		CKT. NO.		LOAD SERVED
A/C COMBO UNIT	A	1	2	A	OFFICE RECEPT
A/C COMBO UNIT	B			B	OFFICE RECEPTS
A/C COMBO UNIT	A	3	4	A	OFFICE RECEPTS
A/C COMBO UNIT	B			B	SPARE
OFFICE RECEPT	A	5	6	A	OFFICE RECEPT
SPARE	B			B	
SPARE	A	7	8	A	OFFICE RECEPT
SPARE	B			B	
SPARE	A	9	10	A	HALLWAY RECEPT
SPARE	B			B	OFFICE LIGHTS
SPARE	A	11	12	A	SPARE
SPARE	B			B	SPARE
SPARE	A	13	14	A	OFFICE LIGHTS
SPARE	B			B	HALLWAY LIGHT
SPARE	A	15	16	A	SPARE
SPARE	B			B	SPARE

PANEL E

125 AMP BUS
120/240 VOLTS
SURFACE MOUNTED

LOAD SERVED	CKT. NO.		CKT. NO.		LOAD SERVED
A/C COMBO UNIT	A	1	2	A	SPARE
A/C COMBO UNIT	B			B	OFFICE RECEPT
A/C COMBO UNIT	A	3	4	A	REF. RECEPT
A/C COMBO UNIT	B			B	SPARE
SPARE	A	5	6	A	OFFICE RECEPT
SPARE	B			B	
FAX RECEPT	A	7	8	A	OFFICE RECEPT
OFFICE RECEPT	B			B	
OFFICE RECEPTS	A	9	10	A	HALLWAY RECEPT
MICROWAVE RECEPT	B			B	OFFICE LIGHTS
SPARE	A	11	12	A	SPARE
SPARE	B			B	TELE RM - RECEPT & LIGHT
SPARE	A	13	14	A	OFFICE LIGHTS
SPARE	B			B	HALWAY LIGHT
SPARE	A	15	16	A	SPARE
SPARE	B			B	SPARE

PANEL F

125 AMP BUS
120/240 VOLTS
SURFACE MOUNTED

LOAD SERVED	CKT. NO.		CKT. NO.		LOAD SERVED
A/C COMBO UNIT	A	1	2	A	MEN'S RECEPTS
A/C COMBO UNIT	B			B	WOMEN'S RECEPTS
A/C COMBO UNIT	A	3	4	A	SPARE
A/C COMBO UNIT	B			B	OFFICE RECEPTS
WOMEN'S RECEPT	A	5	6	A	OFFICE RECEPT
MEN'S RECEPT	B			B	
SPARE	A	7	8	A	OFFICE RECEPT
SPARE	B			B	
OFFICE RECEPTS	A	9	10	A	HALLWAY RECEPT
	B			B	OFFICE LIGHTS
SPARE	A	11	12	A	MEN'S LIGHT & EX FAN
SPARE	B			B	WOMEN'S LIGHT & EX FAN
SPARE	A	13	14	A	OFFICE LIGHTS
SPARE	B			B	HALLWAY LIGHT
SPARE	A	15	16	A	SPARE
SPARE	B			B	SPARE

PANEL G

125 AMP BUS
120/240 VOLTS
SURFACE MOUNTED

LOAD SERVED	CKT. NO.		CKT. NO.		LOAD SERVED
A/C COMBO UNIT	A	1	2	A	OFFICE RECEPTS
A/C COMBO UNIT	B			B	SPARE
A/C COMBO UNIT	A	3	4	A	OFFICE RECEPT
A/C COMBO UNIT	B			B	SPARE
SPARE	A	5	6	A	OFFICE RECEPT
SPARE	B			B	
OFFICE RECEPTS	A	7	8	A	OFFICE RECEPT
SPARE	B			B	
SPARE	A	9	10	A	HALLWAY RECEPT
SPARE	B			B	OFFICE LIGHTS
OFFICE RECEPT	A	11	12	A	SPARE
SPARE	B			B	SPARE
SPARE	A	13	14	A	OFFICE LIGHTS
SPARE	B			B	SPARE
SPARE	A	15	16	A	SPARE
SPARE	B			B	SPARE

PANEL H

125 AMP BUS
120/240 VOLTS
SURFACE MOUNTED

LOAD SERVED	CKT. NO.		CKT. NO.		LOAD SERVED
A/C COMBO UNIT	A	1	2	A	OFFICE RECEPT
A/C COMBO UNIT	B			B	SPARE
A/C COMBO UNIT	A	3	4	A	OFFICE RECEPTS
A/C COMBO UNIT	B			B	SPARE
SPARE	A	5	6	A	OFFICE RECEPT
SPARE	B			B	HALLWAY HEAT
SPARE	A	7	8	A	HALLWAY HEAT
SPARE	B			B	OFFICE RECEPT
OFFICE RECEPTS	A	9	10	A	OFFICE LIGHTS
SPARE	B			B	HALLWAY LIGHT & EM LIGHT
SPARE	A	11	12	A	OFFICE LIGHTS
SPARE	B			B	SPARE
SPARE	A	13	14	A	OFFICE RECEPT
SPARE	B			B	OUTSIDE LIGHT
SPARE	A	15	16	A	SPARE
SPARE	B			B	SPARE

NOTE:
VERIFY ALL DIMENSIONS IN THE FIELD BEFORE PROCEEDING WITH WORK. ANY DISCREPANCIES SHALL BE BROUGHT TO THE ATTENTION OF THE COR AND SHALL BE RESOLVED BEFORE CONTINUING. DO NOT SCALE DRAWINGS.

WARNING: Distribution authorized to U.S. Gov't. agencies & their U.S. contractors Reason: Administrative/Operational Use; 2 December 1996; Other requests for this document shall be referred to: Cdr., USAIC, ATTN: AMSSB-GIO-E APG, MD 21005-5201. DESTRUCTION NOTICE: Destroy by any method that will prevent disclosure of contents or reconstruction of the document.

EDCO CONTRACTORS, INC.
CONSTRUCTION SPECIALIST AND PROJECT MANAGEMENT
819 PHILADELPHIA BLVD
ABERDEEN, MD 21001
410.272.2572

NO.	DATE	REVISION DESCRIPTION	BY
1	8/14/08	ASBUILTS	CDF

DIO

DIRECTORATE OF INSTALLATION OPERATIONS
ENGINEERING & CONSTRUCTION DIVISION
ABERDEEN PROVING GROUND, MARYLAND

T AND M CONSTRUCTION CO INC.
ARCHITECTS, ENGINEERS, SURVEYORS AND CONSTRUCTION MANAGERS
PROFESSIONALS IN DESIGN BUILD CONSTRUCTION
1304 BUSINESS CENTER WAY
SUITE 201
EDGEWOOD, MD. 21040-1501
410-612-6490

DESIGNED	
DRAWN	F. SULLOUGHBY
CHECKED	
DATE	19 MAR 08
SCALE:	NOTED
D.O. NO.	
W.R. NO.	IM 8365M

RENOVATE BUILDING E4504
EDGEWOOD AREA
ABERDEEN PROVING GROUND, MD

E4504 PANEL SCHEDULES

ASB-3
DRAWING NO.

SHEET 3 OF 3

MF#072831

AMSSB-GIO-E FORM REV 01 JUL 02