AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

1. CONTRACT ID CODE	PAGE	OF PAGES
	1	4

2. AMENDMENT/MODIFICATION NO.	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. *(If applicable)*
0001	06/25/2026		

6. ISSUED BY CODE 40LT

USDA-FS CSA INTERMOUNTAIN 8
324 25TH ST
OGDEN UT 84401-2310

7. ADMINISTERED BY *(If other than Item 6)* CODE

8. NAME AND ADDRESS OF CONTRACTOR *(No., street, county, State and ZIP Code)*

CODE FACILITY CODE

(x) 9A. AMENDMENT OF SOLICITATION NO. 1240LT26Q0090

x 9B. DATED *(SEE ITEM 11)* 06/01/2026

10A. MODIFICATION OF CONTRACT/ORDER NO.

10B. DATED *(SEE ITEM 13)*

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☒ is extended, ☐ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended , by one of the following methods: (a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted ; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted , such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA *(If required)*

13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE

A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: *(Specify authority)* THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.

B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES *(such as changes in paying office, appropriation data, etc.)* SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).

C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:

D. OTHER *(Specify type of modification and authority)*

E. IMPORTANT: Contractor ☐ is not ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION *(Organized by UCF section headings, including solicitation/contract subject matter where feasible.)*

POC: Lucas Dahlman Email: ucas.dahlman@usda.gov

The purpose of this amendment is to:

1. Offer an additional Site Visit. Refer to Summary of Changes for Location and Time
2. Extend the Due date from July 13th to July 20th, at 1000 MT
3. Address Questions and Answers
4. See Summary of Changes

FOB: Destination

Period of Performance: 07/20/2026 to 11/30/2027

Continued ...

Except as provided herein, all terms and conditions of the document referenced in Item 9 A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER *(Type or print)*		16A. NAME AND TITLE OF CONTRACTING OFFICER *(Type or print)*	
		LUCAS J. DAHLMAN	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
(Signature of person authorized to sign)		*(Signature of Contracting Officer)*	

NAME OF OFFEROR OR CONTRACTOR

ITEM NO. (A)	SUPPLIES/SERVICES (B)	QUANTITY (C)	UNIT (D)	UNIT PRICE (E)	AMOUNT (F)
	Attachments: C05_Attach 1 - SOI C05_Attach 2 -SOW C05_Attach 3_PUUU_CON Manual C05_Attach 4_PUUU_Drawings C05_Attach 5_WD C020260019-28				

Summary of Changes:

A. An Additional Site Visit on Monday, June 29th at 1000. Meet at:
3751 Mt. Herman Road,
Monument, CO 80132

B. Address Questions asked:

1. My contractor is wanting to ask if the 2 tank removals at Shawnee have to be removed or if they can be crushed and filled in place instead?
   a. ***Old tanks must be removed from site.***

2. What is the earliest the work could start?
   a. ***POP is getting extended to 11/30/2027. Work can most likely begin around the end of July 2026.***

3. Frost free hydrants with all the drawing fittings necessary? Can it be single pipe instead of all the fittings?
   a. ***Bid the spec'd hydrant in the contract.***

4. Plastic Tanks okay?
   a. ***No, concrete tanks required***

5. Do you want foam board under driving surfaces?
   a. ***No, foam insulation around pipe only***

6. Blue poly okay over HDPE okay?
   a. ***No, HDPE required***

7. How do you want driving surfaces recompacted?
   a. ***Salvage road base and wheel compact.***

8. Gasket or glued sdr35 sewer line required?
   a. ***Gasket SDR35 sewer line is required***

9. Can we remove trees if necessary?
   a. ***Yes, but tree removal needs CO approval.***

10. Are county permits required?
    a. ***County permits are not required on Federal Lands.***

11. Grass seeding needed?
    a. ***Will be done by USFS.- Salvage topsoil in all locations.***

12. Can we shut water off at AG and who provides porta John's?
    a. ***Water may be shut off, USFS will provide necessary ports John's to FS employees.***

13. How big is the upper tank at AG?
    a. ***Existing upper tank is 2000 gal, will be replaced with a 1500 gal tank.***

14. Are cleanouts needed at the new tank installations?
    a. ***Bid as is with no clean out.***

Summary of Changes:

15. Does the 16" of fill over the system have to be all topsoil at Lake George?

a. 4 inches minimum of topsoil and the rest (12 on the top and 8 on the sides) being imported road base is acceptable.