UNITED STATES FOREST SERVICE

PROCUREMENT OPERATIONS (PROPS)
EAST ZONE (EZ) TEAM 3 CONSTRUCTION (CONS)

25 June 2026

MEMORANDUM FOR RFQ 12445526Q0073

FROM USFS PROPS EZ 3 CONS

SUBJECT: RFQ 12445526Q0073 Questions & Answers

1. **Question**: "Would [the Government] accept variations of barrel and wing wall shapes as *equal*?"

   Answer: *"Variations of culvert shape (i.e. radiused corners) may be acceptable only if the fabricator can meet the clear cover requirements, steel reinforcing size, and steel reinforcing spacing detailed in the FS drawings. Variations of wing wall shape may be acceptable only if the fabricator can meet the height and width requirements detailed in the FS drawings. The minimum dimensions for the wing wall footing toe (river side) and heel (road side) must be met."*

MATTHEW KILLIAN

Digitally signed by MATTHEW KILLIAN
Date: 2026.06.25 08:25:07 -05'00'

MATTHEW L KILLIAN
Contracting Officer
USFS PROPS EZ 3 CONS