MOUNTAIN LABORATORIES
BULK SAMPLE ANALYSIS FOR ASBESTOS

Mann- Grandstaff VA Medical Center
Chris Warner
4815 N. Assembly Bldg. 32
Spokane, WA 99205

Project: Café & Kitchen Floors

Test Method: 40 CFR, Part 763, Subpart E, Appendix E and EPA/600/R-93/116

Customer #: 1123

Laboratory No.	B26-7130	B26-7131	B26-7132
Sample ID No.	1A	1B	2A
Sample Description	Floor Tile	Floor Tile	Floor Grout
Sample Treatment	Teased/Crushed	Teased/Crushed	Teased/Crushed
Homogeneous	No	No	Yes
Layered	Yes	Yes	No
Fibrous	No	No	No
Sample Color	Tan/Black	Tan/Black	Gray
Asbestos Present	No	No	No
Asbestos Type and Percentage	Tile N.D. Black Layer N.D.	Tile N.D. Black Layer N.D.	N.D.
Total % Asbestos	None	None	None
Other Fibrous Material In Sample			
Non-Fibrous Material	Tile: Other 100% Black Layer: Quartz 60% Other 40%	Tile: Other 100% Black Layer: Quartz 60% Other 40%	Quartz 60% Other 40%

Date Analyzed: February 20, 2026

Analyzed By: Sydney Jeske

Mountain Laboratories, Mountain Laboratories NW, Inc. limits warranty to proper analysis methods only and takes no responsibility for sample procurement. Mountain Laboratories, Mountain Laboratories NW, Inc., 9922 E. Montgomery Suite #13, Spokane Washington 99206 (509) 922-1365 - Fax (509) 922-1380. PLM has been known to miss asbestos in a small percentage of samples. Thus negative or <1% PLM results should be tested with either SEM or TEM. Customer is responsible for sample separation. This report may only be reproduced in full with written approval by Mountain Laboratories. Soil/Dust samples are not covered under NVLAP Accreditation.

Sample results must not be used by the customer to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the Federal Government.

MOUNTAIN LABORATORIES
BULK SAMPLE ANALYSIS FOR ASBESTOS

Mann- Grandstaff VA Medical Center
Chris Warner
4815 N. Assembly Bldg. 32
Spokane, WA 99205

Project: Café & Kitchen Floors

Test Method: 40 CFR, Part 763, Subpart E, Appendix E and EPA/600/R-93/116

Customer #: 1123

Laboratory No.	B26-7133	B26-7134	B26-7135
Sample ID No.	2B	3A	3B
Sample Description	Floor Grout	Terrazo	Terrazo
Sample Treatment	Teased/Crushed	Teased/Crushed	Teased/Crushed
Homogeneous	Yes	Yes	Yes
Layered	No	No	No
Fibrous	No	No	No
Sample Color	Gray	Green	Green
Asbestos Present	No	No	No
Asbestos Type and Percentage	N.D.	N.D.	N.D.
Total % Asbestos	None	None	None
Other Fibrous Material In Sample			
Non-Fibrous Material	Quartz 60% Other 40%	Quartz 15% Oher 85%	Quartz 15% Oher 85%

Date Analyzed: February 20, 2026

Analyzed By: Sydney Jeske

Mountain Laboratories, Mountain Laboratories NW, Inc. limits warranty to proper analysis methods only and takes no responsibility for sample procurement. Mountain Laboratories, Mountain Laboratories NW, Inc., 9922 E. Montgomery Suite #13, Spokane Washington 99206 (509) 922-1365 - Fax (509) 922-1380. PLM has been known to miss asbestos in a small percentage of samples. Thus negative or <1% PLM results should be tested with either SEM or TEM. Customer is responsible for sample separation. This report may only be reproduced in full with written approval by Mountain Laboratories. Soil/Dust samples are not covered under NVLAP Accreditation.

Sample results must not be used by the customer to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the Federal Government.

CHAIN OF CUSTODY RECORD

Mountain Laboratories
9922 E. Montgomery Drive, Suite 13
Spokane Valley, WA 99206
Phone: 509-922-1365
Email: heidi@mountainlaboratories.com

Billing Information (if different)
Contact Name, Address & Phone
Chris Warner
Building 32
Mann-Grandstaff VA Medical Center
4815 N. Assembly St.
Spokane, WA 99205
(509) 434-7000, X6177

Project Name: Cafe & Kitchen Floors

Project No:

Results: (check box)

	PHONE:
x	E-MAIL: christopher.warner@va.gov
	MAIL:

Customer Information

TURNAROUND
- ☐ 1 HR
- ☐ 3 HR
- ☐ 24 HR
- ☒ 48 HR
- ☐ 3 Day
- ☐ 5 Day

SAMPLE #	SAMPLE DESCRIPTION/ID	DATE/TIME	# OF CONTAINERS	PLM - BULK	REMARKS
1A	A007 floor tile	2/17/26	1	x	
1B	A007 floor tile	2/17/26	1	x	
2A	A007 floor grout	2/17/26	1	x	
2B	A007 floor grout	2/17/26	1	x	
3A	B109A terrazo	2/17/26	1	x	
3B	B109A terrazo	2/17/26	1	x	

RELEASED BY (Signature)	DELIVERY METHOD	RECEIVED BY (Signature)	COMPANY	DATE / TIME RECEIVED	CONDITION
[illegible]	Hand	Paige Clapper	Mountain Laboratories	2/18/26 12:55pm	Good