Solicitation: 140P6326Q0027
Lincoln Home National Historic Site-Replace Automatic Glass Doors at Visitor Center
Questions and Answers

Question 1:
Is the plan to just replace the doors and automatics to the doors or the entire store front?

Government Response:
Yes, just the doors and hinges, no store front replacement for this project.

The Contractor shall furnish all labor, materials, equipment, and supervision necessary to provide complete, operational entrance assemblies. New door systems shall be designed to fit within existing aluminum storefront openings. Existing storefront frames shall be modified and reinforced as required to accommodate new heavy-duty, high-cycle entrance doors.

Work includes, but is not limited to, the following:

- Remove and replace two pairs of entry doors and associated hardware (each pair approximately 6'-0" x 7'-0"; field verify).

01 10 00 Division 01 Short Form General Requirements
Page 3 of 29 04/07/2026

Question 2:
Do we need to have a dual cam set up, or can it be single across the top of the one automatic door?

Government Response:
A single camera is required for each set of automatic doors.

Question 3:
If we are doing the doors only are going back with the matching color?

Government Response:
Yes. The replacement doors shall closely match the existing color. Due to age, fading, and weathering of the existing storefront system, an exact color match may not be achievable. The contractor shall propose the finish color for Government review and approval prior to installation.

Question 4:
What do you need to know for quoting like item?

Government Response:
If the Statement of Work (SOW) specifies a brand name or equal item, vendors may quote an equal item. The quoted item must meet or exceed the salient characteristics identified for the referenced brand-name item.