[redacted]

Solicitation Title: NAL CHILLER REPLACEMENT
Solicitation No: 1232SA26R0028
RFQ Issue Date: [redacted]

Contractor Name: [redacted]
Submitted By: [redacted]
Date of RFI: [redacted]

RFI No	Question	Comments
1	Please advise if existing raceways, power/control conduit and feeders may be reused for new chillers.	Yes. If they are in bad condition, please advise USDA/NAL.
2	Please advise if existing breaker may be reused for new chiller. Please see electrical characteristics of proposed new chiller. Yes. Please inform USDA/NAL of condition.	**Electrical Data** Power Supply [V/ph/Hz]: 460/3/60.0 Total Input Power [kW]: 250.2 Min. Circuit Ampacity [A]: 395.0 Max. Circuit Breaker Amps [A]: 700.0 Job FLA [A]: 316.0 Unit Short Circuit Withstand (STD) [kA]: 100
3	Please advise if one of the boilers may be removed from service to rig out the old chiller and rig in the new chiller. See the attached photo for the section of combustion air that we anticipate needing to remove.	Yes, but with limited down time. What is the max down time requested?
4	Please provide the contact information (email address) for the Purchasing Agent as it was not provided in section 4.0 Key Personnel in ATTACHMENT 1 – STATEMENT OF WORK – NAL CHILLER REPLACEMENT.	N/A. Purchasing Agent is not listed in the SOW, 4.0 Key Personnel

[redacted]

[redacted]

[redacted]