AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

BPA NO.	1. CONTRACT ID CODE	PAGE	OF	PAGES
	None	1		2

2. AMENDMENT/MODIFICATION NUMBER	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQ. NUMBER	5. PROJECT NUMBER (if applicable)
0002	06-24-2026	None	NONE

6. ISSUED BY	CODE	7. ADMINISTERED BY (If other than Item 6)	CODE
Department of Veterans Affairs Network Contracting Office (NCO) 2 3495 Bailey Avenue Building 3, 2nd floor Buffalo NY 14215	36C528	Department of Veterans Affairs Network Contracting Office (NCO) 2 3495 Bailey Avenue Building 3, 2nd floor Buffalo NY 14215	36C528

8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code)	(X)	9A. AMENDMENT OF SOLICITATION NUMBER
To all Offerors/Bidders		36C24226Q0642
	[X]	9B. DATED (SEE ITEM 11)
	[ ]	10A. MODIFICATION OF CONTRACT/ORDER NUMBER
		10B. DATED (SEE ITEM 13)
CODE / FACILITY CODE		

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

[X] The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers [X] is extended, [ ] is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified. ** HOUR & DATE for Receipt of Offers is EXTENDED to: 07-13-2026 4:00pm EDT

12. ACCOUNTING AND APPROPRIATION DATA (If required) None

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE	
[ ]	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
[ ]	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
[ ]	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
[ ]	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor [ ] is not, [X] is required to sign this document and return 1 copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

This amendment answers vendor questions in the word document attached below and extends the offer due date to 07/13/2026 at 4:00pm EST.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
		Daniel Zielinski Contracting Officer	
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA (Signature of Contracting Officer)	16C. DATE SIGNED

Site Visit Questions – 06/23

NOTE This solicitation is for chiller and cooling tower water treatment services only. This is NOT for the maintenance of the chillers and cooling towers.

1. Does VA perform in house testing? **No**
2. What are the volumes of the water? **There are three 400 ton electric chillers that can operate simultaneously and then a 400 ton steam absorption chiller that will never operate.**
3. When chemicals need to be used? **Vendor discretion**
4. Is the treatment equipment owned by VA? What does the vendor need to supply? **Vendor shall Inspect and maintain all feeding equipment Vendor provides and/or sells to Customer under this Agreement**
5. Does the vendor need to do a pesticide treatment? **No**
6. What is the annual water volume? **Unknown**
7. How many chilled loops are there? What is the annual loss on the chilled loop? **1 and Unknown.**
8. Do we exclude the chilled loop from the solicitation since numbers are unclear? **NO**
9. Who updates the water management plan? **VA updates the plan** Does the vendor need to provide one? **No vendor does not need to provide one**
10. Where do chemicals get delivered? How are they handled? **According to Vendor SOP to BLD 45**
11. Is there a non-oxidize preference? **No**
12. Is the plumbing to the chillers VA's? **YES**
13. Who owns the containers? Previous Vendor? Will they be changed? **VA owns containers but vendor will use their own equipment**
14. Do we want dual biocides? If so, which one? **Yes, Vendor Discretion**
15. There is a blown down meter. What is the yearly value of it? **Not sure what this is**
16. Is the maintenance/taking heads off included? **NO**
17. How many legionella samples are taken? **Up to 4 per year**
18. What equipment needs to be provided by the vendor? **Vendor shall Inspect and maintain all feeding equipment Vendor provides and/or sells to Customer under this Agreement**