F3G3CE6107A002 - INSTALL FLOW METER FOR FACILITY 1711 Well #12 RFI:

Q. Please advise if installation of the 2" air relief valve is required as it is not specified in the SOO. This requirement would affect both pricing and technical approach.

a. The Air Relief Valve will not be included in the scope for this project.