AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT	1. CONTRACT ID CODE	PAGE 1	OF PAGES 2

2. AMENDMENT/MODIFICATION NO.	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable)
0001	06/17/2026	7581446	

6. ISSUED BY	Code N40085	7. ADMINISTERED BY (If other than item 6.)	Code
CG MCAS Cherry Point FACILITIES, ROICC B-87, 748 Roosevelt Blvd. PSC BOX 8006 CHERRY POINT, NC 28533			

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)	☒	9A. AMENDMENT OF SOLICITATION Refurbish Barracks Facilities, Building 4295 & Building 4296, MAG-14.
		9B. DATED (SEE ITEM 11)
AMENDMENT MUST BE ACKNOWLEDGED WITH YOUR PROPOSAL	☐	10A. MODIFICATION OF CONTRACT/ORDER NO.
		10B. DATED (SEE ITEM 13)
CODE / FACILITY CODE		

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers ☐ **is extended** ☒ **is not extended**. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning 1 copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (if required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

☐	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14. ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
☐	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATION CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103 (b).
☐	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
☐	D. OTHER: (specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not ☐ is required to sign this document and return **original** to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

7581446, Refurbish Barracks Facilities, Building 4295 & Building 4296, Marine Corps Air Station Cherry Point, NC

Amendment 0001 is being issued to answer pre-award inquiries (PPIs).

The deadline to submit pre-award RFI's REMAINS 29 June 2026 at 12:00 PM.

The proposal due date of 06 July 2026 at 12:00 PM local time REMAINS unchanged.

See Attached.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR (Same as Item 8) (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY (Signature of Contracting Officer)	16C. DATE SIGNED

PPI #	DATE SUBMITTED	REFERENCE			QUESTION	GOVERNMENT RESPONSE	POSTED ON AMENDMENT #
		PAGE	SECTION	PARAGRAPH			
1	6/15/2026	1			Are the existing furnishings to be moved to a warehouse location within Cherrry Point or is it the intent for furnishings to be stored within containers on site? If on site, can it be confirmed there will be room enough and easily accessible for the required number of containers? Also, will tyhere be special conditions applicable to the containers such as dehumidifiers or other equipment?	Yes the furnishing shall be stored on site in CTR provided containers that shall be climate controlled.	0001
2	6/15/2026				Since 4295 & 4296 will be concurrent, we request to either eliminate the days given per site and combine the two to 420 days or maintain the current schedule and adjust the days for 4295 to the same as 4296, 270 days. With the applicable liquidated damages on a per day/per room schedule, we feel work on 4296 can be completed within the 270 days spefific to the RFP. howver, based on the scope and irrelevant to work being concurrent, 4295 can't be completed within the 150 days.	The time line requirments shall not change.	0001
3	6/15/2026				Are exterior doors included as part of the door count provided? If so, will the exterior require painting?	No.	0001
4	6/15/2026				Please provide a footage quantity or room dimensions/quantity of rooms, necessary for the amount of cove base required.	Sent Attachment 06/17/2026 A site visit is schedualed for 6/22/26 CTR shall confirm all requirments at that time.	0001
5	6/15/2026				What are the requirements for field staff? Will this require a single person or multiple individuals with singular titles? In addition, can you confirm the same individuals can supervise both 4295 & 4296, even if running concurrent…and not separate of one another?	There shall be multiple individuals, one per BEQ.	0001
6	6/15/2026				Can you confirm the square foot "total" of the closets at 385 is correct?	Sent Attachment 06/17/2026 A site visit is schedualed for 6/22/26 CTR shall confirm all requirments at that time.	0001
7	6/15/2026				Overall quantities for lighting fixtures are given, however a breakdown of each type is not provided. With the material cost for each type varying, we request a breakdown be provided.	Sent Attachment 06/17/2026 A site visit is schedualed for 6/22/26 CTR shall confirm all requirments at that time.	0001
8	6/15/2026				We request a size of the showers be provided. Need to know size of each barracks shower, with count, if there are also showers for the handicapped, and their quantities.	Sent Attachment 06/17/2026 A site visit is schedualed for 6/22/26 CTR shall confirm all requirments at that time.	0001

Subj: AMENDMENT TO WO 7581446 REFURBISH BEQ FACILITIES; B4295 & B4296; MAG 14, MCAS CHERRY POINT NC

CONTINUATION SHEET

<TO ADD DRAWINGS>
DOCUMENT 00 01 15
1.2 CONTRACT DRAWINGS
Add the following to the list of drawings:

NAVFAC DWG NO.	TITLE
4169020 - 4169125	BACHELOR ENLISTED QUARTERS

These drawings accompany this Amendment.