AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

1. CONTRACT ID CODE	PAGE	OF	PAGES
	1		9

2. AMENDMENT/MODIFICATION NUMBER	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQUISITION NUMBER	5. PROJECT NUMBER *(If applicable)*
0001	05/29/2026		

6. ISSUED BY CODE PIA

NPS, IMR - Arizona MABO
1824 S Thompson St, Ste 200
Flagstaff AZ 86001-2694

7.ADMINISTERED BY *(If other than Item 6)* CODE

8. NAME AND ADDRESS OF CONTRACTOR *(Number, street, county, State and ZIP Code)*

CODE | FACILITY CODE

(X) 9A. AMENDMENT OF SOLICITATION NUMBER
140P1526Q0100

[X] 9B. DATED *(SEE ITEM 11)*
05/29/2026

[ ] 10A. MODIFICATION OF CONTRACT/ORDER NUMBER

10B. DATED *(SEE ITEM 13)*

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

[X] The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers [ ] is extended. [X] is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA *(If required)*

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NUMBER AS DESCRIBED IN ITEM 14.

CHECK ONE	
[ ]	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: *(Specify authority)* THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NUMBER IN ITEM 10A.
[ ]	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES *(such as changes in paying office, appropriation data, etc.)* SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
[ ]	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
[ ]	D. OTHER *(Specify type of modification and authority)*

E. IMPORTANT: Contractor [ ] is not [ ] is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (*Organized by UCF section headings, including solicitation/contract subject matter where feasible.)*

See continuation page

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER *(Type or print)*		16A. NAME AND TITLE OF CONTRACTING OFFICER *(Type or print)*	
		Lindsay McLaughlin	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
(Signature of person authorized to sign)		*(Signature of Contracting Officer)*	

NAME OF OFFEROR OR CONTRACTOR

ITEM NO. (A)	SUPPLIES/SERVICES (B)	QUANTITY (C)	UNIT (D)	UNIT PRICE (E)	AMOUNT (F)
	AMENDMENT 0001 is issued to provide Government responses to questions received. Offeror must acknowledge Amendment with quote package. Due date remains unchanged.				

United States Department of the Interior

NATIONAL PARK SERVICE
CONTRACTING OPERATIONS - CENTRAL
1849 C Street
NW Washington, DC 20240

Solicitation #: 140P1526Q0100

Amendment #: 0001

PEFO Replace Housing Lighting

Questions and Government Responses listed below:

Question #	Question	Answer/Response
1	The solicitation title references "Small Structures Refinishing," but the Statement of Work scope appears limited to replacing the two solar streetlights (line item 0010, Lighting Replacement, Lump Sum). Please confirm there is no small-structures refinishing work within the scope of this solicitation. If refinishing work is in scope, please identify it so it can be priced.	The requirement is for two solar streetlights only.
2	We reviewed the SOW and see performance specifications for the solar lighting system, however we do not see a manufacturer, model number, catalog cut sheet, or approved fixture list. Is the contractor expected to provide a fixture meeting the listed specifications, or is there a preferred manufacturer/model that should be quoted?	There is no preferred manufacturer and the contractor is expected to meet listed specifications.
3	Can the existing concrete foundations be reused if they are determined to be structurally sound, or should replacement foundations be included in the bid?	Replacement foundations should be planned for.
4	Wage Determination Attachment: Can the Government confirm if the wage determination attachment is available on SAM.gov? It was listed in the solicitation but was not included in the reviewed package.	Wage determination is attached to the solicitation document under the Attachments header in SAM.gov.
5	Subcontractor SAM.gov Registration: Can the Government clarify whether proposed subcontractors are required to maintain active SAM.gov registration, or if this requirement applies only to the prime offeror/awardee?	This requirement only applies to the Prime.
6	FAR 52.219-14 – Limitations on Subcontracting: Can the Government confirm whether FAR 52.219-14 applies to this acquisition? This clause was not found in the solicitation PDF.	This clause is not included.

7	Subcontractor Past Performance / Prior Experience: If we utilize a qualified subcontractor for installation, may we rely on that subcontractor's relevant experience as part of the technical capability submission?	Subcontractor must be disclosed and it must state so.
8	Questions Deadline: Can the Government confirm that June 15, 2026, at 12:00 PM MT is the controlling deadline for questions, despite language stating questions are due within three calendar days of the site visit?	3 calendar days after the site visit fell on the weekend. Due date was pushed to the next business day.
9	Site Visit Attendance: Are offerors required to attend the site visit to be eligible for award?	Site visit is not mandatory.
10	Arizona Electrical License Classification: Does the Government require a specific Arizona electrical license classification for this project?	No
11	Solar Light Installation Locations: Will the new solar lights be installed at the existing pole locations, or will final locations be identified during the site visit or pre-installation meeting?	Final locations will be identified at pre-installation meeting.
12	Utility Information: Will the Government provide existing utility information, or is the contractor fully responsible for utility locating prior to excavation?	Contractor is fully responsible for utility locating.
13	Foundation Requirements: Are engineered foundation details required, or may the contractor follow the manufacturer's foundation and anchoring recommendations?	The contractor may follow the manufacturers foundation and anchoring recommendations.
14	Payment Administration: Are progress payments allowed, or will payment be issued only upon final acceptance? We request clarification on how payment will be administered under FAR 52.232-27.	The magnitude for this project is less than $25,000.00. If progress payments are needed, it can be discussed at the pre-construction meeting. Progress payments would only be allowable for materials bought, and work that has been performed/completed.

15	Can the Gov't please provide a few photos of each of the existing street lights and their current connection to bases?	
16	Can the Gov't please confirm if power will be available for Contractor use?	Yes, standard 110V power is available.

17	Can the Gov't please confirm if water will be available for Contractor use?	Water is available for use.
18	Can the Gov't please confirm if the existing concrete bases may be allowed to be reutilized as bases for the new street lights?	New concrete bases should be planned for.
19	If new pour-in-place concrete bases are required, will there be any space available for on-site concrete washout?	Yes.

United States Department of the Interior

NATIONAL PARK SERVICE
CONTRACTING OPERATIONS - CENTRAL
1849 C Street
NW Washington, DC 20240

United States Department of the Interior

NATIONAL PARK SERVICE
CONTRACTING OPERATIONS - CENTRAL
1849 C Street
NW Washington, DC 20240

United States Department of the Interior

NATIONAL PARK SERVICE
CONTRACTING OPERATIONS - CENTRAL
1849 C Street
NW Washington, DC 20240