KEY-	No Longer Used	Current Approved Location	MCR/ DMARC/ SPCL	On Site Notes	Matterport Scan	Review Notes
BLDG # (000)	BLDG LEVEL (LVL)	Current Room # MCR/ TR/TE/ DMARC/ SPCL	Exist or Original SOW- MCR/ TR/TE/ DMARC/ SPCL	Site Visit Scan Notes (xx/xx/xx)	Matterport Scan Link Location	Review Notes
001	LVL B	01 (TE)	N/A			Exception Memo - service building from TR 01A
001	LVL G	X	N/A			Exception Memo - service building from TR 01A
001	LVL 01	X	N/A			Exception Memo - service building from TR 01A
007	LVL 00	X	10			Exception Memo - service floor from LVL 01, TR 115
007	LVL 01	115	N/A			
007	LVL 02	209B	N/A			
007	LVL 03	317	N/A			
008	LVL 00	05 (TE)	N/A			
008	LVL 01	108B	N/A			
008	LVL 02	X	211			Exception Memo - service floor from LVL 01, TR 108B
009	LVL 00	X	N/A			
009	LVL 01	119	N/A			Exception Memo - service floor from LVL 01, TR 119
009	LVL 02	211	224	224 - Existing MCR		*228 - Demarc Room
009	LVL 03	309A	N/A			
013	LVL 00	01A	02-09			
013	LVL 01	X	109			Exception Memo - service floor from LVL 00, TR 01A
015E/H	LVL 00	011A	015 & 049	Consolidation		Variance Request - serving B.15E/H from single TR
015E/H	LVL 01	H-140 (Tower)	N/A			
015E/H	LVL 02	H-255 (Tower)	219 & 249	Consolidation		
015E/H	LVL 03	H-301 (Tower)	N/A			Variance Request - serving 4th floor (attic) from 3rd floor TR
016	LVL 00	008	N/A			
016	LVL 01	F-100	F-100	F-100 PBX Backbone		Variance Request - serving 2nd and 3rd floor from F-100
016	LVL 02	X	N/A			Exception Memo - service floor from LVL 02, TR F-100
016	LVL 03	X	N/A			Exception Memo - service floor from LVL 02, TR F-100
017	LVL 00	G-014C	G-104			Overhead piping concern in G-014; move to corner of G-014A approved prior to 95% submittal
017	LVL 01	107	N/A			
017	LVL 02	G-203	N/A			
017	LVL 03	X	N/A			Exception Memo - service floor from LVL 02, TR G-203
018	LVL 00	39	Stair Hall 1			Exception Memo - TR does not meet form factor req's; 1 rack serving floor
018	LVL 01	115A	167 & 168			
018	LVL 02	D-214A	D-221			
018	LVL 03	314CA	N/A			
019	LVL 00	X	C-002			Exception Memo - service floor from LVL 01, TR C-104
019	LVL 01	C-104	N/A			
019	LVL 02	C-208	N/A			
020	LVL 00	X	B-001			Exception Memo - service floor from LVL 01, TR B-122
020	LVL 01	B-122	113A			
020	LVL 02	B-205B	207			
021	LVL 00	X	A-003			Exception Memo - service floor from LVL 01, TR 142
021	LVL 01	142	N/A			
021	LVL 02	203	N/A			
035	LVL 01	104 (TE)	XX			
044	LVL 00	X	N/A			Exception Memo - service floor from LVL 01, TE 101
044	LVL 01	101 (TE)	N/A			
088	LVL 01	006E (TE)	N/A			
111	LVL 01	R-101 (TE)	N/A			