Please insert changes to specifications below here in the addendum:

WWTP SPECIFICATIONS

Division 22-WWTP

1. Specification 221123 – Domestic Water Pumps-WWTP: Part 3 - Execution: **Add** 3.7 A. – Attic Stock: Provide (1) one spare domestic hot water recirculation pump.

2. Specification 221123.13 – Domestic Water Packaged Booster Pumps-WWTP: Part 3 - Execution: **Add** 3.9 A. – Attic Stock: Provide (1) one spare domestic water booster pump and rebuild kit for duplex pump package.

3. Specification 221429– Sump Pumps-WWTP: Part 3 - Execution: **Add** 3.9 A. – Attic Stock: Provide (1) one spare sewage grinder pump for the duplex pump package.

4. Specification 223330– Electric Domestic Water Heaters-WWTP: Part 3 - Execution: **Add** 3.6 A. – Attic Stock: Provide (1) one complete heating element replacement kit, (1) Pressure relief valve, and (1) drain valve

5. Specification 224213.13– Commercial Water Closets-WWTP: Part 3 - Execution: **Add** 3.8 A. – Attic Stock: Provide (1) one complete flush valve replacement assembly

6. Specification 224213.16– Commercial Urinals Closets-WWTP: Part 3 - Execution: **Add** 3.6 A. – Attic Stock: Provide (1) one complete flush valve replacement assembly.

Division 23-WWTP

1. Specification 237416.11 – Packaged Small Capacity Rooftop Air Conditioning Units-WWTP: Part 3 - Execution: **Add** 3.12 A. – Attic Stock: Provide (1) one spare set of filters for each unit.

2. Specification 238126– Split-System Air-Conditioners-WWTP: Part 3 - Execution: **Add** 3.7 A. – Attic Stock: Provide (1) one spare set of filters for each unit.

Division 26-WWTP

1. Specification 260913 – Electrical Power Monitoring and Control-WWTP: Part 3 - Execution: **Add** 3.8 B. – Attic Stock: Provide (1) one spare Surge Protective Device (SPD) for each type of SPD.

2. Specification 262413 – Switchboards-WWTP: Part 1 – General: **Add** 1.5 A. 7 – Provide (1) one spare circuit breaker of each type and size. Provide rebuild kits for larger electronic trip-type circuit breakers.

3. Specification 262416 – Panelboards-WWTP: Part 1 – General: **Add** 1.5 A. 4 – Provide (1) one spare circuit breaker of each type and size. Provide rebuild kits for larger electronic trip-type circuit breakers.

4. Specification 262419 – Motor Control Centers-WWTP: Part 2 – Products: **Add** 2.12 A. 8 – Provide (1) one spare circuit breaker of each type and size. Provide rebuild kits for larger electronic trip-type circuit breakers.

5. Specification 263600 – Transfer Switches-WWTP: Part 2 – Products: **Add** 2.2 K – Provide (1) one set of replacement contacts for the main transfer switch.

6. Specification 264313 – Surge Protection For Low-Voltage Electrical Power Circuits-WWTP: Part 3 - Execution: **Add** 3.4.A – Attic Stock: Provide (1) one spare Surge Protective Device (SPD) for each type of SPD.

Division 41-WWTP

1. Specification 412213.17 – Davit and Gantry Cranes-WWTP: Part 2 - Products: **Add** 2.5.A. – Attic Stock: Provide (1) one set of manufacturer-recommended spare parts for each crane, winch, and winch operator.

Division 43-WWTP

1. Specification 432256 – Submersible Mixers-WWTP: Part 2 - Products: **Add** 2.10.B. – Provide (1) one spare mixer at each WWTP.

2. Specification 432332 – Reclaimed Water Pumping System-WWTP: Part 2 - Products: **Add** 2.8.C. – Provide (1) one spare pump.

Division 46- WWTP

1. Specification 460754 – Package MBR System-WWTP: General, Part 2 - Products: **Add** 2.06.A.1. – Spare parts shall be one full set for each unit, and shall be as recommended by the equipment manufacturers.

2. Specification 431155.02 – DES Polymer Blending System-WWTP: General, Part 2 - Products: **Add** 2.13.A.1. – Spare parts shall be one full set for each WWTP.

3. Specification 431155.03 – Package MBR System-WWTP: General, Part 2 - Products: **Add** 2.08.D. – Provide sufficient lubricant for one year of operation for both the Hospital and Hon-Dah WWTPs.