1. CONTRACT ID CODE	PAGE	OF PAGES
J	1	2

2. AMENDMENT/MODIFICATION NO.	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQ. NO.	PROJECT NO. (If applicable)
0004	04/07/2026		

6. ISSUED BY	Code	N40085	7. ADMINISTERED BY (If other than item 6.)	Code	
NAVFACSYSCOM MID-ATLANTIC ROICC NORFOLK FACILITIES ENGINEERING & ACQ DIV 9324 VIRGINIA AVENUE NORFOLK, VA 23511					

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)		9A. AMENDMENT OF SOLICITATION NO.
	☒	N4008526R0108
	☒	9B. DATED (SEE ITEM 11) 03/09/2026
	☐	10A. MODIFICATION OF CONTRACT/ORDER NO.
		10B. DATED (SEE ITEM 13)
CODE / FACILITY CODE		

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers ☐ **is extended** ☒ **is not extended**. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning _1_ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (if required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

☐ A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14. ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.

☐ B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATION CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103 (b).

☐ C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:

☐ D. OTHER: (specify type of modification and authority)

E. IMPORTANT: Contractor ☒ is not ☐ is required to sign this document and return copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

N4008526R0108; Q-47 DEMOLISH FISHING PIER, NAVAL STATION NORFOLK, NORFOLK, VIRGINIA

See Continuation Page

Contact POC: Hailey McGinness (757) 341-0596; hailey.m.mcginness.civ@us.navy.mil

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR (Same as Item 8) (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY (Signature of Contracting Officer)	16C. DATE SIGNED

SECTION SF30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

AMENDMENT 0004

The purpose of this amendment is to:

1. Provide amended Supplementary Instructions to Offerors document, refer specifically to CLIN AB. See UPDATED ATTACHMENT H_Supplementary Instructions to Offerors.
2. Provide Response to Pre-Proposal Inquiry (PPI) #44 - 47:

PPI #	Date Submitted	LEAVE BLANK	Reference			Question	Responses
			Page	Section	Paragraph		
44						In response to PPI response #7, if the government is performing a post demolition survey to verify the seafloor is clear of obstruction, please confirm that the government is also performing a pre-demolition survey to establish a baseline and confirm that there is no pre-existing debris for which the contractor could potentially be held responsible.	Refer Attach 8C _Bathymetry survey data March 2025 for Govt. pre-demolition survey.
45						In response to PPI response #19, how is the contractor supposed to quantify 'entangled steel/cables' to be manually removed by divers in terms of cubic yards? For reference, 200 CY of steel equals1,323 tons of debris to be removed manually by divers. Please clarify.	See amended ATTACHMENT H_Supplementary Instructions to Offerors, CLIN AB. Delete “near piles to be cut” and replace with “(landside)”.
46						In response to PPI response #20, please confirm that the contractor must establish the current seafloor elevation by means of a bathymetric survey.	Refer Attach 8C _Bathymetry survey data March 2025 for Govt. pre-demolition survey.
47						In response to PPI response #30, please confirm that the contractor work area is not limited to a 30' perimeter around the pier, as our crane barge and material barge are larger.	Limited to size of crane, the barge work area perimeter around pier is acceptable.

All other terms and conditions remain unchanged.

(End of Summary of Changes)