AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

1. CONTRACT ID CODE	PAGE OF PAGES	
	1	3

2. AMENDMENT/MODIFICATION NO.	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO.(If applicable)
0002	27-Aug-2013	ACQR2982495	

6. ISSUED BY	CODE N40085	7. ADMINISTERED BY (If other than item 6)	CODE
NAVFAC MID ATLANTIC NORTHEAST IPT 9742 MARYLAND AVENUE BLDG Z-144 NORFOLK VA 23511		**See Item 6**	

8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		
	X	9A. AMENDMENT OF SOLICITATION NO. N40085-13-R-3528
	X	9B. DATED (SEE ITEM 11) 07-Aug-2013
		10A. MOD. OF CONTRACT/ORDER NO.
		10B. DATED (SEE ITEM 13)
CODE	FACILITY CODE	

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

[X] The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer [ ] is extended, [X] is not extended.

Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

[ ] A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.

[ ] B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).

[ ] C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:

[ ] D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor [ ] is not, [ ] is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

D/B/B for ST09-0447, Pier Complex Structural Repairs - Pier 4, Trestle 1A & 4 at Naval Weapons Station, Colts Neck, NJ

The Purpose of this amendment is as follows:
1. Provide answers for Bid Inquiries
2. Establish Liquidated Damages (LD's) rate at $4,850.00 per day for this project.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) TEL: EMAIL:	
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY (Signature of Contracting Officer)	16C. DATE SIGNED 27-Aug-2013

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:
CONTIINUATION SHEET

Inquiry #1
What is the size of the existing steel fender piles shown on details A1 and A2 on drawing S-503?

Response

The existing fender piles appear to be a W30 steel shape with a tapered top. Size shown is approximate and should be verified in the field prior to fabricating the fiberglass jacket.

Inquiry #2
What are the security requirements for concrete or asphalt delivery trucks to enter the site?

Response

Section 01 14 00, paragraph 1.4.1.2, and subsequent paragraphs, apply to all contractor and subcontractors, including concrete and asphalt delivery trucks.

Inquiry #3
The "under deck concrete repair schedule" on drawings S-602 thru S-607 references repair details on drawing S-503 as D2 and D3. There are no details D2 or D3 on S-503.

Response

On sheet S-503 detail the following changes should be made:

- Detail C2 should be labeled D2
- Detail C3 should be labeled D3
- Detail B4 should be labeled B5

Inquiry #4
The "above deck concrete repair schedule" on drawings S-608 thru S-610 references repair details on S-503 as D3 and B5. There are no details D3 or B5 on S-503.

Response

Please see response to Inquiry #3.

(End of Summary of Changes)