DEPARTMENT OF THE AIR FORCE
AIR FORCE SUSTAINMENT CENTER (AFMC)
HILL AIR FORCE BASE UTAH

Questions and Answers

Notice ID FA820126Q0019

VERTICAL TRANSPORTATION EQUIPMENT MAINTENANCE, REPAIR, & INSPECTION SERVICES

Below are the questions received regarding the aforementioned solicitation that is currently active on SAM.gov. This is currently a **live document** that will be updated with any and all questions received for this solicitation. The final day for email inquiries for this solicitation is **30 June 2026** at **2:00pm MDT**. Once the final question has been added to this document it will no longer be considered a live document. Notice of this change will be stated below.

Current Document Status: Live Document as of 29 June 2026 at 9:20am MDT
Final Document: 30 June 2026 at 2:00pm MDT

- Current incumbent contractor/vendor name?
  - **Mdm Mac Enterprises Inc.**
- Current or prior contract number?
  - **FA820123C0008**
- Previous SAM.gov solicitation number?
  - **0210202375CES**
- Contract award value and/or pricing information, if releasable?
  - **The current contract was awarded at $123,424 for base year services.**
- Contract period of performance
  - **Please see solicitation documents for projected Period of Performance.**
- CLIN 0003 references the "309th/Reimbursable Emergency CLIN" with a quantity of one (1) lot. Could you please clarify what pricing is expected for this line item and how offerors should structure their pricing? It's referencing a qty of 1 "lot". We do not understand what is being asked for from a pricing perspective for this.
  - **CLIN 0003 and CLIN 0006 will not be bid on at this time but are money allocated for emergencies for the year, we keep a running tally for emergency services and items that are not covered under the service plan. It is also used if there is an emergency to get someone out of an elevator. From PWS concerning CLIN 0003 and 0006: 5.2. Emergency Calls. Emergency calls are defined as calls made for services when a VTE system fails and constitutes a danger to personnel; threatens to damage properties; or threatens to disrupt activity, operations, and/or training missions. The contractor shall respond in person to the VTE and begin work on emergency repairs service calls within two hours upon notification by the COR.**
- Can you clarify if "inspections" is just the price for code required testing (CAT 1 & CAT 5) and the maintenance is just the regular preventative maintenance and repairs?
  - **CLIN 0001 and 0004 are for code required inspections and CLIN 0002 and 0005 are for regular preventative maintenance.**

Site Visit Questions:

- Are all units currently up to date with testing?
  - **Yes.**