AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

1. CONTRACT ID CODE	PAGE	OF	PAGES
	1		4

2. AMENDMENT/MODIFICATION NUMBER	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQUISITION NUMBER	5. PROJECT NUMBER *(If applicable)*
0003	07/02/2026		

6. ISSUED BY CODE N40085

NAVFACSYSCOM MID-ATLANTIC
9324 VIRGINIA AVENUE, NORFOLK
NORFOLK, VA 23511-0395
UNITED STATES
Shayna EICHNER, Email shayna.t.eichner.civ@us.navy.mil Telephone: 7573411046

7. ADMINISTERED BY *(If other than Item 6)* CODE

8. NAME AND ADDRESS OF CONTRACTOR *(Number, street, county, State and ZIP Code)*

CODE FACILITY CODE

(X)

☐ 9A. AMENDMENT OF SOLICITATION NUMBER N4008526R0161

9B. DATED *(SEE ITEM 11)* 14 May 2026

☐ 10A. MODIFICATION OF CONTRACT/ORDER NUMBER

10B. DATED *(SEE ITEM 13)*

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended. ☒ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA *(If required)*
See Section 00 70 00 - Conditions of the Contract

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NUMBER AS DESCRIBED IN ITEM 14.

CHECK ONE	
☐	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: *(Specify authority)* THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NUMBER IN ITEM 10A.
☐	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES *(such as changes in paying office, appropriation data, etc.)* SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
☐	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
☐	D. OTHER *(Specify type of modification and authority)*

E. IMPORTANT: Contractor ☐ is not ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (*Organized by UCF section headings, including solicitation/contract subject matter where feasible.)*

See Schedule

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER *(Type or print)*		16A. NAME AND TITLE OF CONTRACTING OFFICER *(Type or print)*	
15B. CONTRACTOR/OFFEROR *(Signature of person authorized to sign)*	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA *(Signature of Contracting Officer)*	16C. DATE SIGNED

SECTION SF30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

Block 14 (Description of Amendment/Modification): Solicitation NO: N4008526R0161, Design-Bid-Build, Phase III Groundwater Treatment Plant, Bethpage, New York

SEE SF 30 BLOCK 14 CONTINUATION PAGE

ALL CORRESPONDENCE REGARDING THIS SOLICITATION SHALL BE DIRECTED VIA EMAIL TO SHAYNA EICHNER AT SHAYNA. T.EICHNER.CIV@US.NAVY.MIL

This amendment is issued to incorporate the following:

1. Provide Interested Vendors List (attached separately).
2. Provide Attachment L- 43 3113.13 10 (attached separately).
3. Provide Attachment N- 08 71 00 R1. (attached separately).
4. Provide Attachment O- 43 21 13_R1 (attached separately).
5. Provide Attachment P- M101-R1 (attached separately).
6. Provide Attachment Q- 50 03 01 R1 (attached separately).
7. Provide Attachment R- A-112G08005-WE24 Phase III- A-102 (attached separately).
8. Provide PPI Responses (enclosed).

SECTION SF30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

The following have been added by full text:

AMENDMENT 0003

This amendment is issued to incorporate the following:

1. Provide Interested Vendors List (attached separately).
2. Provide Attachment L- 43 3113.13 10 (attached separately).
3. Provide Attachment N- 08 71 00 R1. (attached separately).
4. Provide Attachment O- 43 21 13_R1 (attached separately).
5. Provide Attachment P- M101-R1 (attached separately).
6. Provide Attachment Q- 50 03 01 R1 (attached separately).
7. Provide Attachment R- A-112G08005-WE24 Phase III- A-102 (attached separately).
8. Provide PPI Responses (enclosed).

---

1. Provide Interested Vendors List (attached separately).

---

2. Provide Attachment L- 43 3113.13 10 (attached separately).

---

3. Provide Attachment N- 08 71 00 R1. (attached separately).

---

4. Provide Attachment O- 43 21 13_R1 (attached separately).

---

5. Provide Attachment P- M101-R1 (attached separately).

---

6. Provide Attachment Q- 50 03 01 R1 (attached separately).

---

7. Provide Attachment R- A-112G08005-WE24 Phase III- A-102 (attached separately).

---

8. Pre-Proposal Inquiry Responses (enclosed).

PPI #	Page	Section	Paragraph	Question	Response
11		87100	3.6	It appears the hardware sets section of the spec is cut short. They specify a lot of hardware but there is nothing showing which hardware goes with which door. Please issue a completed door hardware schedule.	Drawing A-601, and related drawings, provide the relevant door schedules for this project. Also, see the revised specification attached (Attachment N- 08 71 00 R1)
12	Drawing M-505	467680		Contract drawing M-505 depicts a floating decanter guided by vertical decanter guide posts anchored at the tank bottom and supported at the top. However, spec section 467680 specifies a floating decanter restrained by three stainless steel cables. Please confirm the intended decanter guidance system (guide posts vs. mooring cables) and provide the required operating water range.	Drawing M-505 depicting guiding posts is correct. Please see the revised Attachment Q- 50 03 01 R1. The operating range will be approximately 21 feet and will be field adjusted.
15		Spec Section 43 21 15	2.1.A.8	Specification states that pumps shall fit inside the 6" nominal well casing diameter, however, the Grundfos model 625S pumps specified are 8.31" in diameter and will fit a minimum well diameter of 9". Please advise.	The well casings are a nominal 12 inches, not 6 inches as stated in the specifications. See revised specification 43 21 13 (Attachment O- 43 21 13_R1).
19				I noticed that a coconut carbon is specified, and it is required for the product to be produced in the United States. Coconut carbons are not produced in the US, but rather imported. I would need to know whether we should provide an imported coconut GAC product or a coal-based product manufactured in the US. For this application, we would typically recommend a coal-based catalytic carbon for optimal performance	While coconut shell-based carbon is preferred for this application, acid-rinsed coal-based carbon can also be used. Attached is the revised specification (Attachment L- 43 3113.13 10)

21				"Drawing A-102 as notes call outs for Steel Guardrail, while Structural detailed drawings S-402 & S-503 Call for FRP. Please clarify the desired material. Specifications call for Molded Mesh grating while Notes on Drawing S-003 call for 2" Pultruded Grating T-3300 or T-5000 .Please clarify the desired material. Contract drawing M-101 shows an 8" BWS pump discharge while schematics on drawing MI605 shows 10" BWS pump discharge. Please confirm the size."	Drawing MI605 is correct. The pump suction is 10 inch. Drawing M-101 is being revised to show the 10" BWS pipe size. (Attachment P- M101-R1)