1. Question; Please confirm existing lighting locations are to remain unchanged, and no fixture relocation is anticipated?

Answer: Contractor shall submit a lighting plan using 2x2 led Light dimmable.

2. Question: Please confirm all supply diffusers and return grilles will remain in their existing locations and only require temporary removal and reinstallation.

Answer: The diffusers shall align with light plan.

3. Question: Is the contractor responsible for disconnecting and reconnecting smoke detectors, speakers, sensors or will this work be performed by the government?

Answer: Yes

4. Question: Could the government provide the specifications of the ceiling tile/grid manufacturer?

Answer: Spec is in scope.

5. Question: Please confirm whether repairs to damaged doors, door edges and hinge areas are included or if sanding/prep and painting

Answer: Sand and prep as per scope

6. Question: Please confirm the required quantity of 2x2 LED light fixtures for each room. During site visit, the completed room has smaller fixtures than the existing spaces. If smalling fixtures are required, please confirm whether the fixture count will increase to maintain the required lighting levels or remain the same. (One for one replacement?)

Answer: The lighting plan will determine the quantity for each room.

7. Question: Where will the dumpster be permitted on site for trash removal?

Answer: Yes, the loading dock.

8. Question: Where will materials/equipment be transported into the building?

Answer: N/A

9. Question: Will escorts be required during work operation for all employees?

Answer: NO, All workers will need to get a Fort Belvoir pass.

9. Question: Please confirm the government will remove all furniture and equipment out of the room before work begins.

Answer: Government will remove furniture.