| Location | Local number | JCAHO | Note/Serve's | Milton Cat Ref on old contract REF. | Batteries Last Replaced | Fuel Tanks | Engine Model | Engine Ser# | Gen Model# | Gen Ser# | Engine | GenSet Ser# | Manu Code | Control Panel Ser# |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 VA Center, Augusta, ME inside Building 244 | G-10 | X | B206, B205, B204, B232 | C27 2A300654 | 11-2025 SC | 9 and 10 share 2000 gallon tank | C27 | MJE05062 | SR5 | GDG00623 | | 2A300654 | | |
| 1 VA Center, Augusta, ME OUTSIDE Building 210 | G-11 | X | B210,B248,B203,B235,B255 | C13 T3200659 | 11-2025 SC | 475 gallon tank | C13 | PW300814 | LC6 | G6B25564 | | | | |
| 1 VA Center, Augusta, ME Inside RM 195 in Building 200 | G-4 | X | B200E,B200, B209 | 3412 81z08706 | 11-2025 SC | 4 & 8 Share 2000 gallon tank | 3412DT | 81Z08706 | SR4 | 5NA06607 | | | | |
| 1 VA Center, Augusta, ME Outside Building 249 | G-5 | | | | August 2025 (by VA) | 700 gallon | C18 | CM800198 | LC6 | G6B24696 | | | | |
| 1 VA Center, Augusta, ME Inside Building 238 | G-7 | X | B238,B202,B211,B212,B239,B201 | | 11-2025 SC | feed off 75000 gallon tank | 3406 | 4ZR01263 | SR4B | 9CR00660 | | | | |
| 1 VA Center, Augusta, ME Inside RM 195 in Building 200 | G-8 | X | B200,B209,B237, B246. | 3459 CCB00984 | 11-2025 SC | 4 & 8 Share 2000 gallon tank | 3456 | CER00862 | SR4 | | 7WG01716 | | | |
| 1 VA Center, Augusta, ME inside Building 244 | G-9 | X | B207 | C9 C9EO1997 | August 2025 (by VA) | 9 and 10 share 2000 gallon tank | C9 | S9L03112 | LC5 | G5A04041 | | | | |
| 1 VA Center, Augusta, ME next to Salt Shed | P1 | | Largest Portable | | 02-2023 | 459 gallon | 6090HFG95 | | 432PSL6210 | MT-000582-0714 | | | MMG330-0036 | 1409605 |
| 1 VA Center, Augusta, ME next to Salt Shed | P3 | | Smaller Portable by Salt Shed | | August 2025 (by VA) | 358 gallon | 6068HFG05 | | 431PSL6208 | MT-0042623-0217 | | | MDG150DF4 | 3002791925 |
| 1 VA Center, Augusta, ME Outside Building 249 | P4 | | Smallest portable by B202 | | 11-2025 SC | 165 gallon | 4045HFG04 | | 362NSL1650 | 735894-01 15 | | | MDG100DF4 | 3002876808 |
| 35 State Hospital Dr., Bangor, ME 04401 | P-6 | | Bangor | | 11-2025 SC | 513 gallon | | | | | | | | |
| 15 Challenger Dr., Lewiston, ME 04240 | P-7 | | Lewiston | | 11-2025 SC | 700 gallon | | | | | | | | |
| 1 VA Center, Augusta, ME next to MIOX Building | P-8 | | Ingersol Rand, engine label notes manu by Mitsubishi | | 11-2025 SC | 50 gallon | 4IRS2N-14837 | | | | | | | |