RFP 1605C3-26-R-00008 Questions – Electrical Related

1) Electrical Panel Capacity: Please provide existing panel schedules and available capacity.

   Response: The electrical panels will have to be updated to support the new requirements.

2) Lighting Control Requirements: Please confirm preferred lighting control system or protocol.

   Response: Lighting control system is outside the scope of the engineering. I have transferred this to AV.

3) If an electrical panelboard is found to require replacement due to end-of-life, discontinued parts or unable to find replacement parts, does the existing feeder conduit and wiring need to be replaced back to the source breaker? Will the existing feeder breaker remain, or is replacement required?

   Response: All electrical wiring and breakers will need to be replaced.