AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

1. CONTRACT ID CODE	PAGE	OF	PAGES
J	1		2

2. AMENDMENT/MODIFICATION NUMBER	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQUISITION NUMBER	5. PROJECT NUMBER *(If applicable)*
0001	24 Jun 2026	See Continuation Sheet	

6. ISSUED BY CODE N68171

NAVSUP FLC SIGONELLA NAPLES OFFICE
NAVAL REGIONAL CONTRACTING CEN DET, PSC 817 BOX 50
FPO, AE 09622-0050
UNITED STATES
Anna Guarino, Email: anna.guarino4.ln@us.navy.mil Telephone: 0815683573

7. ADMINISTERED BY *(If other than Item 6)* CODE

SCD: PAS:

8. NAME AND ADDRESS OF CONTRACTOR *(Number, street, county, State and ZIP Code)*

CODE FACILITY CODE

(X)

☒ 9A. AMENDMENT OF SOLICITATION NUMBER N6817126RN006

9B. DATED *(SEE ITEM 11)* 18 Jun 2026

☐ 10A. MODIFICATION OF CONTRACT/ORDER NUMBER

10B. DATED *(SEE ITEM 13)*

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended. ☒ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA *(If required)*

See Section G - Contract Administration Data

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NUMBER AS DESCRIBED IN ITEM 14.

CHECK ONE	
☐	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: *(Specify authority)* THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NUMBER IN ITEM 10A.
☐	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES *(such as changes in paying office, appropriation data, etc.)* SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
☐	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
☐	D. OTHER *(Specify type of modification and authority)*

E. IMPORTANT: Contractor ☐ is not ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (*Organized by UCF section headings, including solicitation/contract subject matter where feasible.)*

See Schedule

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER *(Type or print)*		16A. NAME AND TITLE OF CONTRACTING OFFICER *(Type or print)*	
		Annamaria Guarino	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
(Signature of person authorized to sign)		*(Signature of Contracting Officer)*	24 Jun 2026

Previous edition unusable

STANDARD FORM 30 (REV. 11/2016)
Prescribed by GSA FAR (48 CFR) 53.243

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

Block 14 (Description of Amendment/Modification): The purpose of this Amendment is to provide responses to three (3) Pre-Proposal Inquiries (PPIs):

PPI #1: Can a proposal involving a Turkish or Cyprus shipyard be taken into consideration?

Response: The place of performance geographic restriction is delineated in the Request for Proposals (RFP) Section C - Description/Specifications /Statement of Work (Page 4 of 48), includes all contractors who have a facility along the Mediterranean basin. The Republic of Turkiye and the Republic of Cyprus are within the area of consideration, subject to the conditions established in the geographic limitation.

PPI #2: The following information for item NO. 0003 LCC-SWI-APPROACH BERTHING AND MOORING REQUIREMENTS is required: Arrival Draft (ABL) Aft Mast Top; Estimated Arrival Conditions: Forward Draft; Aft Draft; Displacement; Air Draft;

Response: Arrival Draft (ABL) Aft Mast Top; Estimated Arrival Conditions: Forward Draft: 26 FT - 00 IN; Aft Draft: 26 FT - 10 IN; Draft below lowest Projection (S.W.) 28 FT - 02 IN (MTW's propeller extends below the keel by 2'4"); Displacement: 18,893 LT ; Air Draft: 147 FT 08 IN

PPI #3: Ref: Section 7.1.3 - Shore Steam
Request clarification regarding the steam load expectations.
Based on the specification, the requirement is:
-Supply of shore steam at approximately 145 psi (~10 barg)
-Maximum capacity of 6,000 lb/hr (~2.7 t/h) at the ship's connection
However, the specification does not indicate any minimum steam load or minimum continuous demand.
For the purpose of correctly sizing and operating the boiler equipment, confirm:
-Whether there is a minimum required steam load (continuous or base load) expected during operation ?
This information will help ensure the selected equipment is properly matched to the operational profile and avoids inefficiencies associated with low-load operation.

Response: There is no minimum required steam load. The majority of the steam demand will be for house heating, therefore the demand will be based on ambient weather conditions at the contractor's facility. The contractor should provide equipment that is capable of cycling on/off during periods of low steam demand