DEPARTMENT OF THE NAVY
COMMANDER
NAVAL FACILITIES ENGINEERING SYSTEMS COMMAND PACIFIC
258 MAKALAPA DRIVE SUITE 100
PEARL HARBOR HI 96860-3134

Notice No. 11
July 2, 2026

PRE-PROPOSAL QUESTIONS & ANSWERS

RFP N62742-26-R-1306
JFY 2022 PROJECT J-875, BATTLE STAFF TRAINING FACILITY, U.S. NAVSUPPACT MCB CAMP BLAZ, GUAM

NOTE: The following questions and answers are provided for INFORMATION ONLY. The RFP remains unchanged unless it is amended in writing on a Standard Form 30.

REVISED RESPONSE FROM NOTICE NO. 10:

155. Reference: Drawing SF505, Structural Framing Details
Please specify weight/ft of W8 beam and thickness of L4x4 cont angle at Chiller Enclosure.

ANSWER: Use W8X24 for all beams. Use L4X4X3/8 for the angles. Sheet SF401 was revised to specify weight per foot of W8 beam and thickness of L4x4 angles.

End of Notice