AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

1. CONTRACT ID CODE	PAGE	OF	PAGES
J	1		4

2. AMENDMENT/MODIFICATION NUMBER	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQUISITION NUMBER	5. PROJECT NUMBER *(If applicable)*
0015	08 JUL 2026		26-9

6. ISSUED BY	CODE	7. ADMINISTERED BY *(If other than Item 6)*	CODE
W912DS			

W2SD ENDIST NEW YORK
KO CONTRACTING DIVISION, 26 FEDERAL PLAZA RO(M 16 300
NEW YORK, NY 10278-0004
UNITED STATES
ORLANDO NIEVES, EMAIL: ORLANDO.NIEVES@USAC E.ARMY.MIL TELEPHONE: (917) 790-8078

SCD: PAS:

8. NAME AND ADDRESS OF CONTRACTOR *(Number, street, county, State and ZIP Code)*

( )

☒ 9A. AMENDMENT OF SOLICITATION NUMBER
W912DS26RA015

9B. DATED *(SEE ITEM 11)*
17 APR 2026

☐ 10A. MODIFICATION OF CONTRACT/ORDER NUMBER

10B. DATED *(SEE ITEM 13)*

CODE	FACILITY CODE

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended. ☒ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
(a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA *(If required)*

SEE SECTION G - CONTRACT ADMINISTRATION DATA

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NUMBER AS DESCRIBED IN ITEM 14.

CHECK ONE	
☐	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: *(Specify authority)* THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NUMBER IN ITEM 10A.
☐	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES *(such as changes in paying office, appropriation data, etc.)* SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
☐	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
☐	D. OTHER *(Specify type of modification and authority)*

E. IMPORTANT: Contractor ☐ is not ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (*Organized by UCF section headings, including solicitation/contract subject matter where feasible.)*

See Schedule

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER *(Type or print)*		16A. NAME AND TITLE OF CONTRACTING OFFICER *(Type or print)*	
		MOHENDA R. SURAGE	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
(Signature of person authorized to sign)		*(Signature of Contracting Officer)*	08 JUL 2026

Previous edition unusable

STANDARD FORM 30 (REV. 11/2016)
Prescribed by GSA FAR (48 CFR) 53.243

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

Block 14 (Description of Amendment/Modification): The purpose of this Amendment 0015:
1) Proposals due date remains July 14, 2026 @ 2:00 P.M. EST
2) Respond to Bidder Request for information. For information Only.
3) Specification Sections 23 09 00, 23 09 23.02, Submittal Register and J&A for Johnson Controls Inc Metasys have been revised and reissued.

NOTE: Bidders must acknowledge receipt of this amendment by date specified in the bid (or as amended) by one of the following methods: In the space provided on the SF 1442, by separate letter, or by signing block 15 below. FAILURE TO ACKNOWLEDGE AMENDMENT BY DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR BID IN ACCORDANCE WITH THE LATE BID, LATE MODIFICATION OF BID, OR LATE WITHDRAWAL OF BID (FAR 14.304)

Section 01 00 00 - General Requirements

Miscellaneous text in this section has been modified to:

Watervliet Arsenal

Electrical Switching Station North

W912DS26RA015

Amendment 0015

AMENDMENT 0015 to DRAWINGS and SPECIFICATIONS for Watervliet Arsenal Electrical Switching Station North.

TO OFFERORS

The following changes shall be made to the drawings and specifications.

DRAWINGS

1. The following DRAWINGS have been REVISED but NOT REISSUED:

- None

2. The following DRAWINGS have been REVISED and REISSUED

- None

3. The following DRAWINGS have been ADDED:

- None

4. The following DRAWINGS have been DELETED:

- None

SPECIFICATIONS

1. The following SPECIFICATION SECTIONS have been ADDED and are provided in their entirety herein:

- None

2. The following SPECIFICATIONS SECTIONS have been DELETED in their entirety:

- None

3. The following SPECIFICATIONS SECTIONS have been REVISED and REISSUED:

- 23 09 00

- 23 09 23.02

- Submittal Register

- J&A for Johnson Controls Inc Metasys

4. The following SPECIFICATIONS have been REVISED but NOT REISSUED:

- None

PROPOSER'S QUESTIONS AND GOVERNMENT REPLY

Questions that may be of general interest to all Offerors and/or the Government and that are not readily answered by the proceeding changes will appear below. These questions may have been paraphrased or altered to represent several questions regarding the same subject and/or simply revised to clarify and simplify the question(s). Questions and answers are issued to the Offerors "for information only" and do not revise the solicitation, plans or specifications.

BIDDER INQUIRY 149: From Addendum #3, Response to Bidder Inquiry #11: "References to Niagara and JCI Metasys on the Drawings and in the Specs will be removed. Disregard these references, thank you." Does the removal of Niagara and Metasys allow for controllers from other OEMs (i.e.: Honeywell, Rockwell, etc.) as long as they align with ASHRAE 135 and comply with the project cybersecurity specifications?

RESPONSE: UPDATE! J&A approved for JCI Metasys on June 20th, 2026. See updated spec 23 09 00 and 23 09 23.02 with JCI Metasys remaining in the spec, while removing Niagara. The removal of proprietary references to Niagara is intended to eliminate basis-of-design manufacturer naming only. Proposed controls shall be evaluated on the basis of compliance with the salient characteristics and performance requirements of the Contract Documents, including protocol compliance, cybersecurity requirements, system interoperability, functionality, integration requirements, and all specified operational criteria.

BIDDER INQUIRY 150: In specification 25 10 10 section 1.1 it says "There is an existing Utility Monitoring and Control System (UMCS) which performs supervisory monitoring and supervisory control of base-wide building control systems and utility control systems using ASHRAE 135 (BACnet)". Is the UMCS the Switching Station SCADA system referenced in drawing E-602? Is there an expectation that the DDC/BAS and the UMCS be integrated under a single unifying interface since they are both BACnet based systems?

RESPONSE: The UMCS is not what E-602 is referring to. The DDC/BAS is going to be JCI Metasys. These controls will report under a single unifying, existing interface that all JCI Metasys report under on installation. It is one system, DDC/BAS is typically reserved for discussing building controls while UMCS is the collection of multiple facilities and the network that connects them with a front end / M&C software.