Questions & Answers and Site Photos **Solicitation Amendment no. 2 - Attachment no. 2**	
PARK:	Lava Beds National Monument
TITLE:	Supply & Deliver Metal Roof Shakes
SOLICITATION (RFQ) NUMBER:	140P8426Q0027

Questions and Answers:

QUESTION 1: Is there a drawing of the existing building/roof?

ANSWER: No. The existing roof was installed in-house, no drawing was done. However, a sketch drawing was made and is added into the solicitation for this amendment as Attachment 3.

QUESTION 2: Can you provide a location?

ANSWER: 41°42'46.91"N 121°30'20.87"W

QUESTION 3: Is the roof solid sheeted but sounds like it's not and we would be using 5/8 plywood?

ANSWER: The Structure has a 7/17 OSB overlay already from last time the roof was done.

QUESTION 4: How many squares is the roof?

ANSWER: Approxomately16 - 17 squares

QUESTION 5: It appears that there is a small utility or garage type addition that was added to House #40. Can you please confirm if this is accurate? If so, is this square footage included in the 1,600 suare feet total listed in the solicitation?

ANSWER: The 1,600 square footage does not include the utility/garage addition.

SITE PHOTOS: