AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

BPA NO.	1. CONTRACT ID CODE	PAGE	OF	PAGES
		1		4

2. AMENDMENT/MODIFICATION NUMBER	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQ. NUMBER	5. PROJECT NUMBER (if applicable)
A0002		Unchanged	None

6. ISSUED BY	CODE	7. ADMINISTERED BY (If other than Item 6)	CODE
DEPARTMENT OF VETERANS AFFAIRS NETWORK CONTRACTING OFFICE 23 316 ROBERT STREET N, SUITE 506 SAINT PAUL MN 55101	36C263	DEPARTMENT OF VETERANS AFFAIRS NETWORK CONTRACTING OFFICE 23 316 ROBERT STREET N, SUITE 506 SAINT PAUL MN 55101	

8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code)	(X)	9A. AMENDMENT OF SOLICITATION NUMBER
To all Offerors/Bidders		36C26326Q0838
	X	9B. DATED (SEE ITEM 11)
	☐	10A. MODIFICATION OF CONTRACT/ORDER NUMBER
		10B. DATED (SEE ITEM 13)
CODE / FACILITY CODE		

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

[X] The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers [X] is extended, [ ] is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified. ** HOUR & DATE for Receipt of Offers is EXTENDED to: 07-17-2026 12PM MDT

12. ACCOUNTING AND APPROPRIATION DATA (If required) Unchanged

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE	
☐	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
☐	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
☐	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
☐	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor [ ] is not, [X] is required to sign this document and return 1 copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

The purpose of this amendment is to:
1. Response to vendor questions. See page 2.
2. Extend response deadline to 7/17/2026 at 12PM MT.
3. Add attachments for One Line Drawings and Protective Relay Drawings.
4. All other terms and conditions remain unchanged.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
		Joshua Imdacha Contracting Officer	
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA (Signature of Contracting Officer)	16C. DATE SIGNED

Vendor Question 1	VA Response 1
We are requesting clarification regarding the grounding system and ground-fault protection system. Would the Government be able to provide the one-line drawings for the electrical distribution system to assist offerors in preparing their pricing?	The Government attached the one-line drawing but these are only for reference and may not include everything.
Vendor Question 2	VA Response 2
Will the MV transformers only undergo cleaning, visual inspection and oil sampling, meaning no electrical tests such as Polarization Index, Excitation Current, Turns Ratio, Insulation, and Winding Resistance?	No. As written in the SOW, the requirement includes transformer testing, not only cleaning, visual inspection, and oil sampling. The SOW specifies: *"Oil sampling and testing for 17 medium voltage liquid-filled transformers shall also be included as part of this service."*
Vendor Question 3	VA Response 3
Do LV circuit breakers need to undergo electrical testing?	Yes, per Attachment "VHA Directive 1028" mentions testing and manually exercising the circuit breakers.
Vendor Question 4	VA Response 4
If LV circuit breakers require electrical testing, can they be tested using only secondary injection?	No. LV circuit breakers may include secondary injection as part of the testing process, but they cannot be tested only by secondary injection. Mechanical and functional operation testing is explicitly required by the directive.
Vendor Question 5	VA Response 5
Regarding testing of LV circuit breakers, Attachment "VHA Directive 1028" only mentions testing and manually exercising the circuit breakers. No electrical testing (injection testing) is required?	Yes. VHA Directive 1028 does not require electrical injection testing for LV molded-case circuit breakers. Only manual and mechanical functional testing is required.

Vendor Question 6	VA Response 6
Do any relays need to be tested? How many?	Yes. 3. See VA response 11 and attached file 2. PROTECTIVE RELAYS PICTURES.
Vendor Question 7	VA Response 7
If the relays need testing, please specify whether they are single-phase or three-phase.	Three-phase.
Vendor Question 8	VA Response 8
In section "The Contractor Shall", page 8 - item 13, it is requested to perform the Infrared/thermographic scanning of all the equipment BEFORE and AFTER. Is it really necessary to perform (2) IR scans? This implies a doubling of the price for the IR scan.	Yes, as per the SOW.
Vendor Question 9	VA Response 9
We are requesting clarification regarding the requirement for protective relay testing. The Statement of Work includes protective relays as part of the equipment to be inspected and tested. However, we were unable to locate any protective relays in the Equipment List Breakdown. Can the Government please clarify whether protective relay testing is required for this requirement? If so, please identify the applicable equipment or provide the relay inventory.	They are part of the main switch gears in buildings 35, 36, and 37. There will be one in each of those buildings, a total of 3. Attached to this amendment. See file 2. PROTECTIVE RELAYS PICTURES The Protective Relays Manufacturer: Schweitzer Model/Type: SEL-351A

	Relay Designation (ANSI STD) 50P, 51P