AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

1. CONTRACT ID CODE	PAGE	OF	PAGES
J	1		2

2. AMENDMENT/MODIFICATION NUMBER	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQUISITION NUMBER	5. PROJECT NUMBER *(If applicable)*
0001	09 JUL 2026		

6. ISSUED BY CODE W912WJ

W2SD ENDIST NEW ENGLAND
KO CONTRACTING DIVISION, 696 VIRGINIA ROAD
CONCORD, MA 01742-2751
UNITED STATES
ALICIA LACROSSE, EMAIL: ALICIA.N.LACROSSE@USACE.ARMY.MIL TELEPHONE: 978-318-8902

7. ADMINISTERED BY *(If other than Item 6)* CODE

SCD: PAS:

8. NAME AND ADDRESS OF CONTRACTOR *(Number, street, county, State and ZIP Code)*

CODE FACILITY CODE

(X)	
[X]	9A. AMENDMENT OF SOLICITATION NUMBER W912WJ26QA129 9B. DATED *(SEE ITEM 11)* 06 JUL 2026
[ ]	10A. MODIFICATION OF CONTRACT/ORDER NUMBER 10B. DATED *(SEE ITEM 13)*

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

[X] The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers [ ] is extended. [X] is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA *(If required)*

SEE SECTION G - CONTRACT ADMINISTRATION DATA

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NUMBER AS DESCRIBED IN ITEM 14.

CHECK ONE	
[ ]	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: *(Specify authority)* THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NUMBER IN ITEM 10A.
[ ]	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES *(such as changes in paying office, appropriation data, etc.)* SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
[ ]	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
[ ]	D. OTHER *(Specify type of modification and authority)*

E. IMPORTANT: Contractor [ ] is not [ ] is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (*Organized by UCF section headings, including solicitation/contract subject matter where feasible.)*

Amendment is necessary to provide responses to questions from industry.

Solicitation closing remains July 20, 2026 at 5:00 PM Eastern.

All other terms and conditions remain unchanged.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER *(Type or print)*		16A. NAME AND TITLE OF CONTRACTING OFFICER *(Type or print)*	
		JENNIFER SAMELA	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
(Signature of person authorized to sign)		*(Signature of Contracting Officer)*	09 JUL 2026

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

Section A - Solicitation/Contract Form

The following changes have been made:

Miscellaneous text in this section has been added to:

REQUEST FOR INFORMATION:

QUESTION 1: The Statement of Work states that the completed wood stove and chimney system should be able to pass a certified chimney inspection. The SOW also requires the Contractor to perform an operational test at completion, including checking for smoke leaks, correcting any leaks, and providing written documentation of the operational test results. Please clarify whether the Contractor is required to obtain and submit a final third-party certified chimney inspection after completion of the repairs, or whether the requirement is to complete the work in a code-compliant manner capable of passing inspection and provide the required operational test results?

RESPONSE 1: A third-party certified chimney inspection is not required. The requirement is to complete the work in a code-compliant manner capable of passing inspection and provide the required operational test results. The Contractor is required to complete all work in accordance with the manufacturer's recommendations and to meet current codes for woodstove and chimney liner installation as well as the installation of all products in accordance with manufacturer's recommendations.