

Request For Information

Submitted By: Aaron Chamberlain

Title: CSII

Region: III

Institution: CIM

Project Name: Replace Roofs (Program Phase 1 - 4)

Title: Roof Replacement - Phase 1 Facility B

RFI#: 015

Date: 4/7/2026

Needed By: 4/21/2026

CCM Proj. # I-001123

A/E Proj. # 22-090



RFI Description – Correctional Construction Mentorship Program (CCM)

CCM Field is requesting to use 18 gauge metal for metal plate welded to mullion detail A3.7-6. Metal Plate is not specified in Detail. Please advise.

Location: Plan Set 22-090, FAC B UNIT 2

Attachments

Plan(s) Sht/Detail: CB002 A3.7-6

Specification: N/A

Submittals: N/A

Shop Drawings: Field provided slopes of existing condition to roof

Product Data: N/A

Memo / Letter: N/A

Images: N/A

Other: N/A

drains

Response To RFI – Architecture and Engineering Section

18 gauge is acceptable.

Attachments

Plan(s) Sht/Detail: N/A

Specification: N/A

Submittals: N/A

Shop Drawings: N/A

Product Data: N/A

Memo / Letter: N/A

Images: N/A

Other: N/A

Response By: Eileen Tumlin, Senior Architect

Date: 4/22/2026

Timestamp of Response: [Final A/E