ATTACHMENT E- PHOTO B206 TRANSFORMER LEAKS

13.2 KV
ALLIS-CHALMERS
CHLOREXTOL LIQUID FILLED NETWORK TRANSFORMER
KVA 300
MADE IN U.S.A.
SER 4 176 719
60 CY
THREE PHASE
GALS LIQUID
7.3 % IMP
VOLTAGE 13750-480Y/277
FB-1
TAP CHANGER
POS
CONNECTS
DISCONNECT AND GROUNDING SWITCH WITH ELECTRICAL INTERLOCK
INTERLOCK COIL
61-2959-05-069

ALLIS-CHALMERS
CHLOREXTOL LIQUID FILLED NETWORK TRANSFORMER
KVA 300
MADE IN U.S.A.
SER 4 176 720
60 CY
THREE PHASE
GALS LIQUID
7.3 % IMP
VOLTAGE 13750-480Y/277
FA-1
TAP CHANGER
POS
CONNECTS
DISCONNECT AND GROUNDING SWITCH WITH ELECTRICAL INTERLOCK
INTERLOCK COIL
61-2959-05-069
This
TS
Call
www.