AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

1. CONTRACT ID CODE	PAGE	OF	PAGES
	1		3

2. AMENDMENT/MODIFICATION NUMBER	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQUISITION NUMBER	5. PROJECT NUMBER *(If applicable)*
0002	08/11/2026		

6. ISSUED BY CODE WAD-SAP-S

WAD-SAP
7600 Sand Point Way NE
SEATTLE WA 98115

7. ADMINISTERED BY *(If other than Item 6)* CODE

8. NAME AND ADDRESS OF CONTRACTOR *(Number, street, county, State and ZIP Code)*

CODE | FACILITY CODE

(X) 9A. AMENDMENT OF SOLICITATION NUMBER
1305M326Q0374

[X] 9B. DATED *(SEE ITEM 11)*
07/29/2026

[ ] 10A. MODIFICATION OF CONTRACT/ORDER NUMBER

10B. DATED *(SEE ITEM 13)*

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

[X] The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers [X] is extended. [ ] is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA *(If required)*

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NUMBER AS DESCRIBED IN ITEM 14.

CHECK ONE

[ ] A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: *(Specify authority)* THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NUMBER IN ITEM 10A.

[ ] B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES *(such as changes in paying office, appropriation data, etc.)* SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).

[ ] C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:

[ ] D. OTHER *(Specify type of modification and authority)*

E. IMPORTANT: Contractor [ ] is not [ ] is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (*Organized by UCF section headings, including solicitation/contract subject matter where feasible.)*

See continuation page

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER *(Type or print)*		16A. NAME AND TITLE OF CONTRACTING OFFICER *(Type or print)*	
		JENNA L. TAULMAN	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
(Signature of person authorized to sign)		*(Signature of Contracting Officer)*	

Previous edition unusable

STANDARD FORM 30 (REV. 11/2016)
Prescribed by GSA FAR (48 CFR) 53.243

NAME OF OFFEROR OR CONTRACTOR

ITEM NO. (A)	SUPPLIES/SERVICES (B)	QUANTITY (C)	UNIT (D)	UNIT PRICE (E)	AMOUNT (F)
	The purpose of this amendment is to provide responses to questions received, and extend the due date of quotes by one day. Quotes are due August 14, 2026 at 1:00 PM Eastern Time.				

Requests For Information (RFIs)
Project Title: NEFSC Woods Hole Facility's Cottage Building Exterior Trim and Siding Repair and Paint
RFQ/RFP Number: 1305M326Q0374

RFI #	Date Recv'd	RFI	Client/SME Response	Date sent to Ktrs
1	08/06/26	RFI No. 1 – Gutters The existing gutters will need to be temporarily removed to facilitate replacement of the siding and trim. Please confirm whether the Contractor is required to remove and reinstall the existing gutters or if replacement is anticipated under this contract.	Replacement of the gutters are not anticipated and not in the scope of the work. The SOW does not mandate the gutters removed, If the vendor's proposal calls for the gutters to be removed, then the gutters and downspouts shall be reinstalled properly.	8/11/2026
2	08/06/26	RFI No. 2 – Sheathing and Fasteners The condition of the existing wall sheathing and fasteners cannot be determined until the existing cedar shingles are removed. Does the Government intend to provide an allowance for replacement of deteriorated sheathing and damaged fasteners, or should the Contractor should carry an allowance to replacement included in the base bid?	Seathing replacement is not anticipated, nor in the scope of this project.	8/11/2026
3	08/06/26	RFI No. 3 – Screen Door Please clarify whether the existing screen door is to be restored and reinstalled or replaced with a new unit. If replacement is required, please provide the desired material, finish, and any applicable specifications.	Replacement of the Screen door is not in the scope of this project. Screen door can be removed disposed of.	8/11/2026
4	08/06/26	RFI No. 4 – Dumpster Please identify the approved location for the dumpster and advise if there are any restrictions on the maximum size or duration it may remain on site.	The Dumpster can be stagged in the parking lot in front of the cottage. THIS PARKING LOT IS NOT SECURED. Portable vendor provided restroom can also be stagged in the lot. There is no size limitations, the dumpester MUST stay in the lot. It also must be removed when contractors are no longer onsite or at end of POP at the very latest. Preference is a more timely removal.	8/11/2026
5	08/06/26	RFI No. 5 – Temporary Utilities Will the Government provide access to water and electrical power for construction activities at no cost to the Contractor, or should temporary utility services be included in the Contractor's pricing?	Reasonable use Water and Power will be provided by Gov for contractors.	8/11/2026
6	08/06/26	RFI No. 6 – Project Schedule / Weather Conditions Can the Government confirm the anticipated period of performance? Specifically, is construction expected to occur during the fall/winter of 2026 or be deferred until the spring of 2027? This information will help us evaluate weather-related impacts on siding installation, painting, and curing requirements.	The Government would like all work to be completed by the end of October, as to not go into the winter season. The Government is willing to consider quotes which defer the POP until spring, and will select the quote with the best value for the government.	8/11/2026
7	08/06/26	RFI No. 7 – Entrance Wooden Gutter The entrance area includes an existing wooden gutter. Please confirm whether this gutter is to be: a. Removed and replaced in kind to match the existing appearance; or b. Replaced with a metal gutter system; or c. Preserved and repaired only.	This gutter is to be removed and replaced with metal to match the other gutters installed.	8/11/2026
8	08/06/26	RFI No. 8 – Solicitation Will an extension be provided?	Yes, the Government will extend the due dates of quotations with Amendment 0002.	8/11/2026