B09 Amendment 0002-Questions for AK-KENAI NWR-RANGER RESIDENCE WATER FILTRATION SYSTEM **140FC126Q0030.**

1. We understand that the arsenic level exceeds the MCL. Has an arsenic speciation test been performed to determine whether the arsenic is primarily trivalent (As III) or pentavalent (As V)?

Answer: No, this testing has not been completed.

2. What is the maximum required flow rate (GPM) for the system?

Answer: Flow rate is per output of the well pump. I am not positive as to exactly what that maximum capacity is but the minimum flow rate for a residential well would be 10 gpm.