- Will storage on-site for furniture be allowed?
    - There is not a lot of room on-site for a storage container for furniture during the project that won't interfere with site access. Plan for storage off-site that is secure. One day for loading and unloading a pod may be acceptable. Please include assumptions and project plan for storage in purpose.

- Will the Contractor be responsible for moving and storing electronic equipment? (computer, monitors, printers, radios, etc)
    - It is the contractor's responsibility to remove, store, and reinstall all furniture and packed boxes to the rooms and conditions they were before the start of the project. This may include monitors, peripheral electronics, etc. FS fire personnel will move laptops, radio/communication equipment, and printers.

- Will a dumpster be allowed to be left on site?
    - A dumpster may be approved to be left onsite during construction if it can be located so as not to impede access, security, and safety. It will not be allowed to be placed near a building but will be within 100 feet

- What is the required area to be left for employees to work out of during the project?
    - There will be a varying number of employees working from the building during implementation depending on fire activity. Depending on the time of year and duration, we may be able to vacate the building completely, but actual implementation needs will be determined after award and once a schedule for the work is known. Plan for having employee access to at a minimum of one large room for their operations and workstations at a time during installation. This could be the conference room and then move to another room as needed. Please include your plan for this in your proposal.

- Can work be done on the weekends?
    - Work is not allowed on the weekends.

- How was the mastic from the carpet removed by the previous contractor?
    - Unknown.

- Is griding of the concrete for a more level and adhesive surface required?
    - It is required to follow manufacturer's recommendations for installation. State in proposal all assumptions and need to ensure warranties are kept.

- Can an alternative material for the offices be recommended?
    - Yes, if the proposed materials are not suitable for the installation and warranties cannot be met, propose a different material in your proposal, state why and all assumptions.

Activity: Jeffco ATB Flooring

Date: 7·29·26

Last Name	First Name	Company	[redacted]	Email Address
Mack	Kevin	Elegantepoxy		info@elegantepoxy.com
Urbanczyk	Blaine	Stonhard		lourbanczyk@stonhard.com
Ochs	Tom	Wildcross		Tom@WCC5.com
Lopez	Alfonso	Interior Flooring		interiorflooring@outlook.com
Allen	Tanner	KHC		Tanner.KHC@gmail.com
Scott	Laungenslager	ATLAS		SCOTT@ATLASCONCRETESOLUTIONS.COM
Young	Talon	413 Construction		Talon413construction@yahoo.com
Howell	Dan	Mile High Epoxy		Milehighepoxysolutions@gmail.com
Duck	Zory	FCI		Zory.duck@hcfloors.com
Efrem	Woldu	InfinityBox LLC		Efrem@infinity.com
Sauve	Nick	Sauve Construction		Nick@SauveConstruction.com
Christian	Morgan	AHS		Christianmorgan@gmail.com
Martinez	Mike	Accountable Home		info@accountablehomeservice.com