HGS Engineering, Inc.

1121 Noble Street
Anniston, AL 36201
Phone: 256-236-1848 • Fax: 256-236-2979
www.hgsengineeringinc.com

ENGINEERING AND PROFESSIONAL SERVICES

AHERA 6-Month Asbestos Surveillance

G.V. (Sonny) Montgomery VA Medical Center

APRIL 2025

AHERA 6-MONTH ASBESTOS SURVEILLANCE – Background

HGS Engineering, Inc was contracted by the Jackson, Mississippi Department of Veterans Affairs Medical Center Safety Department office to conduct the visual surveillance of asbestos at the Jackson, Mississippi VAMC. This contract required HGS to visually inspect the condition of all friable asbestos-containing materials with the potential for damage and previously identified damaged non-friable asbestos that may have become friable as required by AHERA.

AHERA 6-MONTH ASBESTOS SURVEILLANCE – Inspectors and Dates

Tim Thompson, certified asbestos inspector, and management planner inspected the Jackson VAMC. The inspection conducted on April 23, 2025 at the Jackson VAMC, Mr. Thompson was escorted by Falicia Edwards, Environmental Protection Specialist/ GEMS Program Manager.

AHERA 6-MONTH ASBESTOS SURVEILLANCE – Inspections

At the Jackson VAMC HGS inspected 2 buildings; the main hospital and the R&E Building.

HGS used the asbestos assessment sheets to locate the asbestos-containing materials and visually inspect the condition of the material. A surveillance sheet has been attached with the inspection date and material conditions.

Tim Thompson

Timothy Thompson

Digitally signed by Timothy Thompson
Date: 2025.05.16 08:55:36 -05'00'

Tim Thompson
State of Mississippi DEQ Asbestos Inspector ABI-00007993
Asbestos Supervisor ABS-00007992

Main Hospital: Basement

Room/Location	Title	Campus	Sample #	Homogeneous Designation	Building	Floor	AHERA Class	Material Description	Drawing #	Friable	ACM Status	Material Condition	AHERA Category	Contact	Air	Vibration	Potential for Damage	Response Action	VA Comments
E-3	TSI	MS VMAC	JVA-M-B-W2	TSI WRAP	Main	Basement	TSI	Pipe Wrap	MS VMAC Basement	N	2% Chrysotile	Good	1	Moderate	High	High	3	Leave In Place until Renovation	
E-3	TSI	MS VMAC	JVA-M-B-T1	TSI WRAP	Main	Basement	TSI	Equipment Wrap	MS VMAC Basement	Y	35% Chrysotile- 2% Chrysotile	Good	1	Moderate	High	High	3	Leave In Place until Renovation	
F-40	Floor	Jackson Mississippi VMAC	NESHAP April 2022 F40/1,F401-2,3	TSI Mastic/Wrap	Main	Basement	TSI	TSI Mastic/Wrap	Jackson MS VMAC Main 1st Floor	N	3% Chrysotile- 5% Chrysotile	Good	1	High	High	High	3	Leave In Place until Renovation	
C-45	Floor	Jackson Mississippi VMAC	NESHAP Nov 2017 B-C-46-4	Viinyll Sheet Flooring- Off White	Main	Basement	Miscellaneous	Black Mastic	Jackson MS VMAC Main 1st Floor	N	2% chrysotile	Good	1	High	Low	High	3	Leave In Place until Renovation	
C-46	Floor	Jackson Mississippi VMAC	NESHAP Nov 2017 B-C-46-4	Viinyll Sheet Flooring- Off White	Main	Basement	Miscellaneous	Black Mastic	Jackson MS VMAC Main 1st Floor	N	2% chrysotile	Good	1	High	Low	High	3	Leave In Place until Renovation	
C-52	Floor	Jackson Mississippi VMAC	NESHAP Nov 2017 B-C-46-4	Viinyll Sheet Flooring- Off White	Main	Basement	Miscellaneous	Black Mastic	Jackson MS VMAC Main 1st Floor	N	2% chrysotile	Good	1	High	Low	High	3	Leave In Place until Renovation	
C-52A	Floor	Jackson Mississippi VMAC	NESHAP Nov 2017 B-C-46-4	Viinyll Sheet Flooring- Off White	Main	Basement	Miscellaneous	Black Mastic	Jackson MS VMAC Main 1st Floor	N	2% chrysotile	Good	1	High	Low	High	3	Leave In Place until Renovation	
C-53	Floor	Jackson Mississippi VMAC	NESHAP Nov 2017 B-C-46-4	Viinyll Sheet Flooring- Off White	Main	Basement	Miscellaneous	Black Mastic	Jackson MS VMAC Main 1st Floor	N	2% chrysotile	Good	1	High	Low	High	3	Leave In Place until Renovation	
F-47	Floor	Jackson Mississippi VMAC	Presumed	9x9 Green Tile	Main	1st	Miscellaneous	9x9 Green Tile	Jackson MS VMAC Main 1st Floor	N	Presumed	Good	1	High	High	High	3	Leave In Place until Renovation	
F-47 A	Floor	Jackson Mississippi VMAC	Presumed	9x9 Green Tile	Main	1st	Miscellaneous	9x9 Green Tile	Jackson MS VMAC Main 1st Floor	N	Presumed	Good	1	High	High	High	3	Leave In Place until Renovation	
B-17	Floor	Jackson Mississippi VMAC	NESHAP June 2018 B17	12x12 Whaite and tan tile	Main	1st	Miscellaneous	Tile 12x12 white and tan tile / black mastic	Jackson MS VMAC Main 1st Floor	N	5% Chrysotile	Good	1	High	High	High	3	Leave In Place until Renovation	
B-12	Floor	Jackson Mississippi VMAC	Presumed	Wooden sheet flooring	Main	1st	Miscellaneous	wooden sheet floor covering ?	Jackson MS VMAC Main 1st Floor	N	Presumed	Good	1	High	High	High	3	Leave In Place until Renovation	
C-32	Floor	Jackson Mississippi VMAC	NESHAP Aonl 2022 C32-1,2	12x12 Whaite and tan tile	Main	1st	Miscellaneous	Tile 12x12 white and tan tile / black mastic	Jackson MS VMAC Main 1st Floor	N	3% Chrysotile	Good	1	High	High	High	3	Leave In Place until Renovation	
F-11	Floor	Jackson Mississippi VMAC	NESHAP May 2019 F-11	12x12 Whaite and tan tile	Main	1st	Miscellaneous	Tile 12x12 white and tan tile / black mastic	Jackson MS VMAC Main 1st Floor	N	5% Chrysotile	Good	1	High	High	High	3	Leave In Place until Renovation	
F-24	Floor	Jackson Mississippi VMAC	NESHAP May 2019 F-23	12x12 Whaite and tan tile	Main	1st	Miscellaneous	Tile 12x12 white and tan tile / black mastic	Jackson MS VMAC Main 1st Floor	N	2% chrysotile	Good	1	High	High	High	3	Leave In Place until Renovation	

Main Hospital: 1st Floor

Room/Location	Title	Campus	Sample #	Homogeneous Designation	Building	Floor	AHERA Class	Material Description	Drawing #	Friable	ACM Status	Material Condition	AHERA Category	Contact	Air	Vibration	Potential for Damage	Response Action	VA Comments
A-104 IT	Floor	Jackson Mississippi VMAC	JVA-M-A104-1/2	Green and Brown Striped Tile Flooring	Main	1st	Miscellaneous	Plaster	Jackson MS VMAC Main 1st Floor	N	2,3,7,5% Chrystile	Good	1	High	High	High	3	Leave In Place until Renovation	
F-102	Floor	Jackson Mississippi VMAC	Kitchen 1-4	9X9 Tile	Main	1st	Miscellaneous	Flooring	Jackson MS VMAC Main 1st Floor	N	3,5,7% Chrysotile	Good	1	High	High	High	3	Leave In Place until Renovation	
F-115	Floor	Jackson Mississippi VMAC	Kitchen 5-6	9X9 Tile	Main	1st	Miscellaneous	Flooring	Jackson MS VMAC Main 1st Floor	N	3,5,7% Chrysotile	Good	1	High	High	High	3	Leave In Place until Renovation	
B-113A	Floor	Jackson Mississippi VMAC	JVA-M-4-3,4	Off white 12x12 tile	Main	1st	Miscellaneous	12x12 Off white tile/Black Mastic	Jackson MS VMAC Main 1st Floor	N	2% Chrysotile / 3% Chrysotile	Good	1	High	High	High	3	Leave In Place until Renovation	
C-152	Floor	Jackson Mississippi VMAC	NESHAP June 2018 C-152,C-141	Carpet	Main	1st	Miscellaneous	Mastic under Green Carpet	Jackson MS VMAC Main 1st Floor	N	4% Chrysotile	Good	1	High	High	High	3	Leave In Place until Renovation	
C-154	Floor	Jackson Mississippi VMAC	NESHAP June 2018 C-152,C-141	Carpet	Main	1st	Miscellaneous	Mastic and 12x12 white tile under carpet	Jackson MS VMAC Main 1st Floor	N	5% , 7% Chrysotile	Good	1	High	High	High	3	Leave In Place until Renovation	
C-105A	Floor	Jackson Mississippi VMAC	Persumed	Not Sampled but renovated	Main	1st	Miscellaneous	Not Sampled but renovated	Jackson MS VMAC Main 1st Floor	N	Persumed	Good	1	High	High	High	3	Leave In Place until Renovation	
C-106	Floor	Jackson Mississippi VMAC	Persumed	Not Sampled but renovated	Main	1st	Miscellaneous	Not Sampled but renovated	Jackson MS VMAC Main 1st Floor	N	Persumed	Good	1	High	High	High	3	Leave In Place until Renovation	
C-127E	Floor	Jackson Mississippi VMAC	Persumed	Not Sampled but renovated	Main	1st	Miscellaneous	Not Sampled but renovated	Jackson MS VMAC Main 1st Floor	N	Persumed	Good	1	High	High	High	3	Leave In Place until Renovation	
C-106C	Floor	Jackson Mississippi VMAC	Persumed	Not Sampled but renovated	Main	1st	Miscellaneous	Not Sampled but renovated	Jackson MS VMAC Main 1st Floor	N	Persumed	Good	1	High	High	High	3	Leave In Place until Renovation	
C-106D	Floor	Jackson Mississippi VMAC	Persumed	Not Sampled but renovated	Main	1st	Miscellaneous	Not Sampled but renovated	Jackson MS VMAC Main 1st Floor	N	Persumed	Good	1	High	High	High	3	Leave In Place until Renovation	
C-106D Corridor	Floor	Jackson Mississippi VMAC	Persumed	Not Sampled but renovated	Main	1st	Miscellaneous	Not Sampled but renovated	Jackson MS VMAC Main 1st Floor	N	Persumed	Good	1	High	High	High	3	Leave In Place until Renovation	
G-101	TSI	Jackson Mississippi VMAC	JVA-Boiler-8	Pipe elbow Unit #6C (must use Ladder)	Boiler	1st	TSI	Green Wraped Pipe (white wrap/Black bitumious mastic)	Jackson MS VMAC Main 1st Floor	N	10,15% Chrysotile	Good	1	Low	Moderate	Low	2	Leave In Place until Renovation	
G-101	TSI	Jackson Mississippi VMAC	Boiler 10	TSI Wrap	Boiler	1st	TSI	Air Handler	Jackson MS VMAC Main 1st Floor	N	5% Chrysotile	Good	1	Low	Moderate	Low	2	Leave In Place until Renovation	

Main Hospital: 2nd Floor

Room/Location	Title	Campus	Sample #	Homogeneous Designation	Building	Floor	AHERA Class	Material Description	Drawing #	Friable	ACM Status	Material Condition	AHERA Category	Contact	Air	Vibration	Potential for Damage	Response Action	VA Comments
B218	Floor	MS VMAC	JVA-M-4-3,4	Tan 12x12 Tile	Main	Main 2nd	Miscellaneous	12x12 Tan tile / Black Mastic	MS VMAC Main 2nd	N	2% Chrysotile / 3% Chrysotile	Good	1	High	Low	High	3	Leave In Place until Renovation	

Main Hospital: 3nd Floor

Room/Location	Title	Campus	Sample #	Homogeneous Designation	Building	Floor	AHERA Class	Material Description	Drawing #	Friable	ACM Status	Material Condition	AHERA Category	Contact	Air	Vibration	Potential for Damage	Response Action	VA Comments
B322	Floor	MS VMAC	JVA-M-4-3,4	Off White 12x12 Tile	Main	Main 2nd	miscellaneous	12x12 Off white tile/Black Mastic	MS VMAC Main 2nd	N	2% Chrysotile / 3% Chrysotile	Good	1	Low	Moderate	Moderate	2	Leave In Place until Renovation	
A345	Floor	MS VMAC	JVA-M-3-3/4	Brown Floor Tile	Main	Main 3rd	Miscellaneous	Brown Tile	MS VMAC Main 3nd	N	5% Chrysotile - 3% Chrysotile	Good	1	High	High	High	3	Leave In Place until Renovation	
Fire Ext between A351-352	Floor																		
CORRIDOR A307-A311	Floor	MS VMAC	JVA-M-3-2	White and Grey Striped Flooring	Main	Main 3rd	Miscellaneous	White and Grey Striped Flooring	MS VMAC Main 3nd	N	2% Chrystoile	Good	1	High	High	High	3	Leave In Place until Renovation	
CORRIDOR A336A-A344	Floor	MS VMAC	JVA-M-3-2	White and Grey Striped Flooring	Main	Main 3rd	Miscellaneous	White and Grey Striped Flooring	MS VMAC Main 3nd	N	2% Chrystoile	Good	1	High	High	High	3	Leave In Place until Renovation	
CORRIDOR A345-A349	Floor	MS VMAC	JVA-M-3-2	White and Grey Striped Flooring	Main	Main 3rd	Miscellaneous	White and Grey Striped Flooring	MS VMAC Main 3nd	N	2% Chrystoile	Good	1	High	High	High	3	Leave In Place until Renovation	
CORRIDOR A356-A359	Floor	MS VMAC	JVA-M-3-2	White and Grey Striped Flooring	Main	Main 3rd	Miscellaneous	White and Grey Striped Flooring	MS VMAC Main 3nd	N	2% Chrystoile	Good	1	High	High	High	3	Leave In Place until Renovation	

Main Hospital: 4th Floor

Room/Location	Title	Campus	Sample #	Homogeneous Designation	Building	Floor	AHERA Class	Material Description	Drawing #	Friable	ACM Status	Material Condition	AHERA Category	Contact	Air	Vibration	Potential for Damage	Response Action	VA Comments
4222	Floor	MS VMAC	JVA M-4-3/4	White and Gray Striped Floor Tile	Main	Main 4th	Miscellaneous	9X9 Tile	MS VMAC 4th Floor	N	2% Chrysotile	Good	1	High	High	High	3	Leave In Place until Renovation	

R&E Building Sub-Basement

Room/Location	Title	Campus	Sample #	Homogeneous Designation	Building	Floor	AHERA Class	Material Description	Drawing #	Friable	ACM Status	Material Condition	AHERA Category	Contact	Air	Vibration	Potential for Damage	Response Action	VA Comments
SB-04	Floor	MS VMAC	JVA-RE-SB-1/2	Creama nd Brown Floor Tile	R&E	Sub-basement	Miscellaneous	Cream and Brown Striped	MS VMAC R&E SB First Floor	N	2% Chysotile Tile and Mastic	Good	1	Low	Low	High	3	Leave in untiil replacement	
SB-05A	Floor	MS VMAC	JVA-RE-2-2	White and Beige Tile Floor	R&E	Sub-basement	Miscellaneous	White and Beige Tile	MS VMAC R&E 2nd Floor	N	Floor tile ND, mastic 3% Chroostile	Good	1	Low	Low	High	3	Leave alone until replacement	
SB-06	Floor	MS VMAC	JVA-RE-2-2	White and Beige Tile Floor	R&E	Sub-basement	Miscellaneous	White and Beige Tile	MS VMAC R&E 2nd Floor	N	Floor tile ND, mastic 3% Chroostile	Good	1	Low	Low	High	3	Leave alone until replacement	
SB-08A	Floor	MS VMAC	JVA-RE-2-2	White and Beige Tile Floor	R&E	Sub-basement	Miscellaneous	White and Beige Tile	MS VMAC R&E 2nd Floor	N	Floor tile ND, mastic 3% Chroostile	Good	1	Low	Low	High	3	Leave alone until replacement	
SB-8B	Floor	MS VMAC	JVA-RE-2-2	White and Beige Tile Floor	R&E	Sub-basement	Miscellaneous	White and Beige Tile	MS VMAC R&E 2nd Floor	N	Floor tile ND, mastic 3% Chroostile	Good	1	Low	Low	High	3	Leave alone until replacement	
SB-07	Floor	MS VMAC	JVA-RE-SB-1/2	Creama nd Brown Floor Tile	R&E	Sub-basement	Miscellaneous	Cream and Brown Striped	MS VMAC R&E SB First Floor	N	2% Chysotile Tile and Mastic	Good	1	Low	Low	High	3	Leave in untiil replacement	
SB-07 A	Floor	MS VMAC	JVA-RE-SB-1/2	Creama nd Brown Floor Tile	R&E	Sub-basement	Miscellaneous	Cream and Brown Striped	MS VMAC R&E SB First Floor	N	2% Chysotile Tile and Mastic	Good	1	Low	Low	High	3	Leave in untiil replacement	
SB-07 B	Floor	MS VMAC	JVA-RE-SB-1/2	Creama nd Brown Floor Tile	R&E	Sub-basement	Miscellaneous	Cream and Brown Striped	MS VMAC R&E SB First Floor	N	2% Chysotile Tile and Mastic	Good	1	Low	Low	High	3	Leave in untiil replacement	
SB-07 C	Floor	MS VMAC	JVA-RE-SB-1/2	Creama nd Brown Floor Tile	R&E	Sub-basement	Miscellaneous	Cream and Brown Striped	MS VMAC R&E SB First Floor	N	2% Chysotile Tile and Mastic	Good	1	Low	Low	High	3	Leave in untiil replacement	
SB-07 D	Floor	MS VMAC	JVA-RE-SB-1/2	Creama nd Brown Floor Tile	R&E	Sub-basement	Miscellaneous	Cream and Brown Striped	MS VMAC R&E SB First Floor	N	2% Chysotile Tile and Mastic	Good	1	Low	Low	High	3	Leave in untiil replacement	

R&E Building 2nd Floor

Room/Location	Title	Campus	Sample #	Homogeneous Designation	Building	Floor	AHERA Class	Material Description	Drawing #	Friable	ACM Status	Material Condition	AHERA Category	Contact	Air	Vibration	Potential for Damage	Response Action	VA Comments
200 (Elevator Lobby)	Floor	MS VMAC	JVA-RE-2-2	White and Beige Tile Floor	R&E	2nd Floor	Miscellaneous	White and Beige Tile	MS VMAC R&E 2nd Floor	N	Floor tile ND, mastic 3% Chroostile	Good	1	Low	Low	High	3	Leave alone until replacement	
223 (Elevator Lobby)	Floor	MS VMAC	JVA-RE-2-2	White and Beige Tile Floor	R&E	2nd Floor	Miscellaneous	White and Beige Tile	MS VMAC R&E 2nd Floor	N	Floor tile ND, mastic 3% Chroostile	Good	1	Low	Low	High	3	Leave alone until replacement	

R&E Building 4th Floor

Room/Location	Title	Campus	Sample #	Homogeneous Designation	Building	Floor	AHERA Class	Material Description	Drawing #	Friable	ACM Status	Material Condition	AHERA Category	Contact	Air	Vibration	Potential for Damage	Response Action	VA Comments
400 (Elevator Lobby)	Floor	MS VMAC	JVA-RE-403 JVA-RE-420-1	Off white green striped 12x12 tile	R&E	4th Floor	Miscellaneous	White and Green Striped	MS VMAC R&E 4th Floor	N	3% Chrysotile tile and mastic	Good	1	Low	Low	High	3	Leave in until replacement	
403	Floor	MS VMAC	JVA-RE-403 JVA-RE-420-1	Off white green striped 12x12 tile	R&E	4th Floor	Miscellaneous	White and Green Striped	MS VMAC R&E 4th Floor	N	3% Chrysotile tile and mastic	Good	1	Low	Low	High	3	Leave in until replacement	
403A	Floor	MS VMAC	JVA-RE-403 JVA-RE-420-1	Off white green striped 12x12 tile	R&E	4th Floor	Miscellaneous	White and Green Striped	MS VMAC R&E 4th Floor	N	3% Chrysotile tile and mastic	Good	1	Low	Low	High	3	Leave in until replacement	
405	Floor	MS VMAC	JVA-RE-403 JVA-RE-420-1	Off white green striped 12x12 tile	R&E	4th Floor	Miscellaneous	White and Green Striped	MS VMAC R&E 4th Floor	N	3% Chrysotile tile and mastic	Good	1	Low	Low	High	3	Leave in until replacement	
405A	Floor	MS VMAC	JVA-RE-403 JVA-RE-420-1	Off white green striped 12x12 tile	R&E	4th Floor	Miscellaneous	White and Green Striped	MS VMAC R&E 4th Floor	N	3% Chrysotile tile and mastic	Good	1	Low	Low	High	3	Leave in until replacement	
407	Floor	MS VMAC	JVA-RE-403 JVA-RE-420-1	Off white green striped 12x12 tile	R&E	4th Floor	Miscellaneous	White and Green Striped	MS VMAC R&E 4th Floor	N	3% Chrysotile tile and mastic	Good	1	Low	Low	High	3	Leave in until replacement	
409	Floor	MS VMAC	JVA-RE-403 JVA-RE-420-1	Off white green striped 12x12 tile	R&E	4th Floor	Miscellaneous	White and Green Striped	MS VMAC R&E 4th Floor	N	3% Chrysotile tile and mastic	Good	1	Low	Low	High	3	Leave in until replacement	
411	Floor	MS VMAC	JVA-RE-403 JVA-RE-420-1	Off white green striped 12x12 tile	R&E	4th Floor	Miscellaneous	White and Green Striped	MS VMAC R&E 4th Floor	N	3% Chrysotile tile and mastic	Good	1	Low	Low	High	3	Leave in until replacement	
411A	Floor	MS VMAC	JVA-RE-403 JVA-RE-420-1	Off white green striped 12x12 tile	R&E	4th Floor	Miscellaneous	White and Green Striped	MS VMAC R&E 4th Floor	N	3% Chrysotile tile and mastic	Good	1	Low	Low	High	3	Leave in until replacement	
413	Floor	MS VMAC	JVA-RE-403 JVA-RE-420-1	Off white green striped 12x12 tile	R&E	4th Floor	Miscellaneous	White and Green Striped	MS VMAC R&E 4th Floor	N	3% Chrysotile tile and mastic	Good	1	Low	Low	High	3	Leave in until replacement	
415	Floor	MS VMAC	JVA-RE-403 JVA-RE-420-1	Off white green striped 12x12 tile	R&E	4th Floor	Miscellaneous	White and Green Striped	MS VMAC R&E 4th Floor	N	3% Chrysotile tile and mastic	Good	1	Low	Low	High	3	Leave in until replacement	
417A	Floor	MS VMAC	JVA-RE-403 JVA-RE-420-1	Off white green striped 12x12 tile	R&E	4th Floor	Miscellaneous	White and Green Striped	MS VMAC R&E 4th Floor	N	3% Chrysotile tile and mastic	Good	1	Low	Low	High	3	Leave in until replacement	
423 (Elevator Lobby)	Floor	MS VMAC	JVA-RE-403 JVA-RE-420-1	Off white green striped 12x12 tile	R&E	4th Floor	Miscellaneous	White and Green Striped	MS VMAC R&E 4th Floor	N	3% Chrysotile tile and mastic	Good	1	Low	Low	High	3	Leave in until replacement	
422	Floor	MS VMAC	JVA-RE-403 JVA-RE-420-1	Off white green striped 12x12 tile	R&E	4th Floor	Miscellaneous	White and Green Striped	MS VMAC R&E 4th Floor	N	3% Chrysotile tile and mastic	Good	1	Low	Low	High	3	Leave in until replacement	
R420	Floor	MS VMAC	JVA-RE-403 JVA-RE-420-1	Off white green striped 12x12 tile	R&E	4th Floor	Miscellaneous	White and Green Striped	MS VMAC R&E 4th Floor	N	3% Chrysotile tile and mastic	Good	1	Low	Low	High	3	Leave in until replacement	
R422A	Floor	MS VMAC	JVA-RE-403 JVA-RE-420-1	Off white green striped 12x12 tile	R&E	4th Floor	Miscellaneous	White and Green Striped	MS VMAC R&E 4th Floor	N	3% Chrysotile tile and mastic	Good	1	Low	Low	High	3	Leave in until replacement	
418	Floor	MS VMAC	JVA-RE-403 JVA-RE-420-1	Off white green striped 12x12 tile	R&E	4th Floor	Miscellaneous	White and Green Striped	MS VMAC R&E 4th Floor	N	3% Chrysotile tile and mastic	Good	1	Low	Low	High	3	Leave in until replacement	
416	Floor	MS VMAC	JVA-RE-403 JVA-RE-420-1	Off white green striped 12x12 tile	R&E	4th Floor	Miscellaneous	White and Green Striped	MS VMAC R&E 4th Floor	N	3% Chrysotile tile and mastic	Good	1	Low	Low	High	3	Leave in until replacement	
414	Floor	MS VMAC	JVA-RE-403 JVA-RE-420-1	Off white green striped 12x12 tile	R&E	4th Floor	Miscellaneous	White and Green Striped	MS VMAC R&E 4th Floor	N	3% Chrysotile tile and mastic	Good	1	Low	Low	High	3	Leave in until replacement	
R414A	Floor	MS VMAC	JVA-RE-403 JVA-RE-420-1	Off white green striped 12x12 tile	R&E	4th Floor	Miscellaneous	White and Green Striped	MS VMAC R&E 4th Floor	N	3% Chrysotile tile and mastic	Good	1	Low	Low	High	3	Leave in until replacement	
412A	Floor	MS VMAC	JVA-RE-403 JVA-RE-420-1	Off white green striped 12x12 tile	R&E	4th Floor	Miscellaneous	White and Green Striped	MS VMAC R&E 4th Floor	N	3% Chrysotile tile and mastic	Good	1	Low	Low	High	3	Leave in until replacement	
410	Floor	MS VMAC	JVA-RE-403 JVA-RE-420-1	Off white green striped 12x12 tile	R&E	4th Floor	Miscellaneous	White and Green Striped	MS VMAC R&E 4th Floor	N	3% Chrysotile tile and mastic	Good	1	Low	Low	High	3	Leave in until replacement	
408	Floor	MS VMAC	JVA-RE-403 JVA-RE-420-1	Off white green striped 12x12 tile	R&E	4th Floor	Miscellaneous	White and Green Striped	MS VMAC R&E 4th Floor	N	3% Chrysotile tile and mastic	Good	1	Low	Low	High	3	Leave in until replacement	
406	Floor	MS VMAC	JVA-RE-403 JVA-RE-420-1	Off white green striped 12x12 tile	R&E	4th Floor	Miscellaneous	White and Green Striped	MS VMAC R&E 4th Floor	N	3% Chrysotile tile and mastic	Good	1	Low	Low	High	3	Leave in until replacement	
402	Floor	MS VMAC	JVA-RE-403 JVA-RE-420-1	Off white green striped 12x12 tile	R&E	4th Floor	Miscellaneous	White and Green Striped	MS VMAC R&E 4th Floor	N	3% Chrysotile tile and mastic	Good	1	Low	Low	High	3	Leave in until replacement	

State of Mississippi

Department of Environmental Quality

Office of Pollution Control

Certificate of Licensure

In accordance with the Asbestos Abatement Accreditation and Certification Act,
Enacted as 1989 Mississippi Law, Chapter 505

Be it known that

Timothy A Thompson

Having submitted acceptable evidence of qualifications and
training and other appropriate information, is hereby granted this

Asbestos Inspector

Certification

D Greg Mallery

Chief, Asbestos & Lead Branch

Certificate No.: ABI-00007993
Expiration Date: Mar 4th, 2026
Training Expires on Mar 4th, 2026

70515 LIC20250002

State of Mississippi

Department of Environmental Quality

Office of Pollution Control

Certificate of Licensure

In accordance with the Asbestos Abatement Accreditation and Certification Act,
Enacted as 1989 Mississippi Law, Chapter 505

Be it known that

Timothy A Thompson

Having submitted acceptable evidence of qualifications and
training and other appropriate information, is hereby granted this

Asbestos Supervisor

Certification

Certificate No.: ABS-00007992
Expiration Date: Mar 4th, 2026
Training Expires on Mar 4th, 2026

Chief, Asbestos & Lead Branch

70515 LIC20250001