AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

1. CONTRACT ID CODE	PAGE	OF	PAGES
	1		2

2. AMENDMENT/MODIFICATION NUMBER	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQUISITION NUMBER	5. PROJECT NUMBER *(If applicable)*
A0001	07/21/2026		

6. ISSUED BY CODE

Indian Health Service - DES Seattle
701 5th Avenue, Suite 1600
Seattle, WA 98104

7. ADMINISTERED BY *(If other than Item 6)* CODE

8. NAME AND ADDRESS OF CONTRACTOR *(Number, street, county, State and ZIP Code)*

CODE FACILITY CODE

(X)

☒ 9A. AMENDMENT OF SOLICITATION NUMBER: 75H70126R00034

9B. DATED *(SEE ITEM 11)*: 07/15/2026

☐ 10A. MODIFICATION OF CONTRACT/ORDER NUMBER

10B. DATED *(SEE ITEM 13)*

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended. ☒ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA *(If required)*

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NUMBER AS DESCRIBED IN ITEM 14.

CHECK ONE	
☐	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: *(Specify authority)* THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NUMBER IN ITEM 10A.
☐	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES *(such as changes in paying office, appropriation data, etc.)* SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
☐	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
☐	D. OTHER *(Specify type of modification and authority)*

E. IMPORTANT: Contractor ☐ is not ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (*Organized by UCF section headings, including solicitation/contract subject matter where feasible.)*

A. The purpose of this amendment is to 1) Provide a Q&A sheet as of 7/21/2026, and 2) Replace Attachment J02 Statement of Work, March 2026 version with Attachment J02 Statement of Work R1 July 2026 version. See attached B01 Attachment J02 Statement of Work R1.

B. All other terms and conditions of this solicitation remain unchanged.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER *(Type or print)*		16A. NAME AND TITLE OF CONTRACTING OFFICER *(Type or print)*	
		JONG KIM, Contracting Officer	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
(Signature of person authorized to sign)		*(Signature of Contracting Officer)*	

Amend No.	Item #	Date Submitted	Question Type (Technical or Admin)	Question	Response Date	Response	Responded By
EXAMPLE	0	11/23/2020	Technical	Please provide drawings or plans for ???	11/23/2020	IHS Response	IHS POC
A0001	1	7/17/2026	Technical	I'm reaching out to see if you can help answer a question regarding the roofing membrane for this project. We typically use GAF products and would like to confirm whether they are approved for use on this project.	07/21/2026	The membrane installed must be compatible with the existing roof pvc membrane to ensure a watertight tie in where it may meet portions of the roof that will not be replaced. The product used must be compatibal pvc membrane roofing and must not compromise performance or manufacturers warranty. See SOW paragraphs1.E. and 2.E.	IHS COR
A0001	2	7/19/2026	Technical	The insulation is specified as both R30 and 7" minimum. R30 is equal to 2 layers of 2.6" ISO (total of 5.2") while 7" would equal R41. We just need to clarify what to install.	07/21/2026	The minimum R-value required is R30. The thinnest insullation over the roof shall meet this requirement.	IHS COR
A0001	3	7/19/2026	Technical	The scope states that the ISO should be mechanically fastened but doesn't clarify how to install the cover board and membrane. Both the cover board and the membrane can be installed by either mechanical fastening or adhesion. I recommend adhering them which provides a better hail resistant assembly.	07/21/2026	The cover board and membrane shall be fastened by both adhesion and mechanically. Pine Ridge experiences extremely high wind events.	IHS COR
A0001	4	7/19/2026	Technical	Cover board is readily available in both 1/4" and 1/2" thick boards but the spec does not specify a thickness. I recommend 1/2" as it provides better hail resistance at only a slightly higher cost.	07/21/2026	1/2" cover board shall be installed	IHS COR
A0001	5	7/19/2026	Technical	The spec calls for replacing the parapet flashings. Does this include the existing metal coping cap? The existing metal coping is in good condition and could be reinstalled once the new membrane is installed on the walls. This would easily save $10,000 - $15,000 in material costs alone.	07/21/2026	If the contractor can guarantee replacement of any metal coping cap that is bent or damaged as a result of its removal and re-installation, then re-using the coping cap will be acceptable.	IHS COR
A0001	6	7/19/2026	Technical	Concerning the warranty, we offer various warranties including the 15 year specified in the specification. I recommend clarifying that the Duro-Last 15 Year NDL (No-Dollar-Limit) Supreme warranty is required. In addition to covering the material and labor for 15 years this warranty also covers consequential (interior) damages, all at no extra charge! (See attached warranty sample.)	07/21/2026	See revised SOW paragraph 2.B. for warranty requirements.	IHS COR
A0001	7	7/19/2026	Technical	Is there interest in sustainability? Duro-Last has a "Recycle Your Roof" program (see attached flyer) and the EPDM and ISO could be repurposed through a company called "Repurposed Materials" (repurposedMATERIALS - Largest Industrial Thrift Store in America)	07/21/2026	The contractor is responsible for the disposal of the roof membrane, insulation, and all other removed materials as required by this project. The method of disposal is not specified.	IHS COR