AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

1. CONTRACT ID CODE	PAGE	OF	PAGES
	1		4

2. AMENDMENT/MODIFICATION NUMBER	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQUISITION NUMBER	5. PROJECT NUMBER *(If applicable)*
0001	08/05/2026		

6. ISSUED BY CODE LHA

BLM OR-ST OFC PROC MGMT BR(OR952)
1220 SW 3rd Avenue, 12th Floor
PORTLAND OR 97204

7.ADMINISTERED BY *(If other than Item 6)* CODE

8. NAME AND ADDRESS OF CONTRACTOR *(Number, street, county, State and ZIP Code)*

CODE | FACILITY CODE

(X) 9A. AMENDMENT OF SOLICITATION NUMBER
140L4326Q0093

[X] 9B. DATED *(SEE ITEM 11)*
07/28/2026

10A. MODIFICATION OF CONTRACT/ORDER NUMBER

[ ]

10B. DATED *(SEE ITEM 13)*

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

[X] The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers [X] is extended. [ ] is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA *(If required)*

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NUMBER AS DESCRIBED IN ITEM 14.

CHECK ONE	
[ ]	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: *(Specify authority)* THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NUMBER IN ITEM 10A.
[ ]	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES *(such as changes in paying office, appropriation data, etc.)* SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
[ ]	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
[ ]	D. OTHER *(Specify type of modification and authority)*

E. IMPORTANT: Contractor [ ] is not [ ] is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (*Organized by UCF section headings, including solicitation/contract subject matter where feasible.)*

See continuation page

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER *(Type or print)*		16A. NAME AND TITLE OF CONTRACTING OFFICER *(Type or print)*	
		Kevin Cochran	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
(Signature of person authorized to sign)		*(Signature of Contracting Officer)*	

NAME OF OFFEROR OR CONTRACTOR

ITEM NO. (A)	SUPPLIES/SERVICES (B)	QUANTITY (C)	UNIT (D)	UNIT PRICE (E)	AMOUNT (F)
	The purpose of this amendment is to extend the response due date and provide responses to questions received for solicitation 140L4326Q0093 KFFO Gerber Well Back-Up Generator. See Continuation pages for questions and responses.				

Questions with responses received for Solicitation # 140L4326Q0093 KFFO Gerber Well Back-Up Generator

1. QUESTION: Is diesel the preferred fuel type?

   RESPONSE: Diesel, Gasoline or Propane are all acceptable.

2. QUESTION: Is the required output 120/240V, single-phase?

   RESPONSE: Yes

3. QUESTION: Does the 150-amp requirement represent the continuous connected load, or is it the rating of the automatic transfer switch (ATS)?

   RESPONSE: The generator should be able to deliver up to 150-amps at 120/240-volt single phase.

4. QUESTION: Are there any significant motor-starting loads, such as a well pump? If so, could you please provide the motor horsepower and starting method?

   RESPONSE: The main requirement for power is the 20hp 480-v 3-p well pump. The well pump is fed via a VFD that converts the 120/240-volt single phase input power to 480-V 3-P secondary power via the VFD for the well pump.

5. Is the trailer required to be DOT road-legal or will it primarily be used for onsite storage and movement?

   RESPONSE: Needs to be DOT road-legal

6. Are there any specific requirements for weatherproofing, sound attenuation, cold-weather equipment, or battery charging?

   RESPONSE: The unit will be stored outdoors and in-service May-October and stored indoors during winter months. Appropriate weather proofing such as block heaters for diesel powered units would be needed to handle weather conditions during the month in-service.

7. What is the required delivery date?

   RESPONSE: Flexible but no later than May 2027

8. Is installation or connection to the automatic transfer switch (ATS) included in the scope of work?

   RESPONSE: Installation is not included/required in the scope of work

9. What style of trailer hitch mount would they like? Ball, 2" or 2 5/16, or pintle?

   RESPONSE: 2 or 2 5/16 hitch is acceptable.

10. Would they like trailer brakes, and if so electric or hydraulic?

    RESPONSE: Electric trailer breaks.

11. Some models are backordered until late November. Is that acceptable or would they prefer a slightly larger/smaller model with a quicker turnaround time?

    RESPONSE: Models that are quoted with a November backorder date are fine if it is delivered prior to May of 2027.

12. QUESTION: In looking at the general requirements, it does not show any power cabling as part of the bid package. Can you confirm that this is correct?

    RESPONSE: Yes, that is correct.

13. QUESTION: Please verify Voltage is 120/240 SINGLE PHASE ONLY.

    RESPONSE: The generator should be able to deliver up to 150-amps at 120/240-volt single phase.

14. The Statement of Work specifies a minimum 120/240-volt, 150-amp, 36 kW generator; however, it does not indicate whether the required electrical service is single-phase or three-phase. Could you please confirm the required phase configuration so that we can obtain accurate pricing and propose the correct equipment?

    RESPONSE: The generator should be able to deliver up to 150-amps at 120/240-volt single phase.