AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

1. CONTRACT ID CODE	PAGE	OF	PAGES
	1		2

2. AMENDMENT/MODIFICAITON NO.	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicble)
AMENDMENT NO. 0004	8/4/26		26-0433

6. ISSUED BY CODE N40085

NAVFAC Mid-Atlantic
Resident Officer in Charge of Construction
1107A Birch Street
Camp Lejeune, NC 28547-2521

7. ADMINISTERED BY (If other than Item 6) CODE

See Item 6

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)

CODE FACILITY CODE

(X) ✘

9A. AMENDMENT OF SOLICIATION NO.
N40085-26-R-9054

9B. DATED (SEE ITEM 11)
7/8/26

10A. MODIFICATION OF CONTRACT/ORDER NO.

10B. DATED (SEE ITEM 11)

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☒ is extended, ☐ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a)By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPIRATION DATA (If required)

13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE	
	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not, ☐ is required to sign this document and return ——— copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

26-0433, BEQ M400 Area Paint-Flooring Repairs
Amendment 0004, Requests for Information

The date and time for receipt of proposals has been extended to 13 August 2026 at 2pm.

This amendment should be acknowledged when your proposal is submitted. Failure to acknowledge the amendment may constitute grounds for rejection of a proposal.

See Continuation Page(s)

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA (Signature of Contracting Officer)	16C. DATE SIGNED

CONTINUATION SHEET

1. QUESTION: Please identify the controlling document for finish selections to be used for bidding and installation, including paint colors/sheens, LVT color/pattern, epoxy resinous flooring system/color, and any carpet selections if applicable. The Scope of Work references attached product specifications and finish specifications, and Section 09 65 00 requires color, pattern, and texture as indicated on the drawings or in the Project Scope of Work, while Section 09 68 00 states that color, texture, and pattern are to be in accordance with the drawings. Please confirm which attachment or drawing sheet is the governing finish schedule where multiple attachments may exist.

ANSWER: Attachment "BEQ M400 Area Carpet and Paint Specs" has been provided.

2. QUESTION: Please confirm whether moisture, alkalinity, and bond testing of existing concrete substrates is required as part of this project for all flooring replacement areas, and if so, which standard governs each flooring type and whether testing reports are required prior to installation. Section 09 65 00 references ASTM F1869 and ASTM F2170 and lists 'Moisture, Alkalinity and Bond Tests' as a required submittal item, while Section 09 68 00 requires moisture and alkalinity tests in accordance with CRI 104/105 for carpeting. The Scope of Work describes LVT and epoxy resinous flooring replacement but does not identify where carpeting, if any, remains in scope.

ANSWER: Any carpet in sleeping rooms will be replaced with LVT and any carpet in common areas will be replaced with Epoxy.

3. All other terms and conditions remain unchanged.