DEPARTMENT OF THE AIR FORCE
48TH FORCE SUPPORT SQUADRON
RAF LAKENHEATH

04 AUGUST 2026

MEMORANDUM FOR RECORD

FROM: 48 CONS/PKA

SUBJECT: FA558726Q0040 - Diesel Sewage Pump – Vendor Questions

1. **Where will the pump be installed?**
   - The pump will be installed at RAF Lakenheath, specifically at Building 1019, Sewage Treatment Works.
2. **Is there an IMO number and serial number (ship) / or serial number (industry etc.) for reference?**
   - Unfortunately, I do not have this information.
3. **Is this a new pump installation or replacement of an existing pump?**
   - This is a brand-new asset for the team, not a new installation or replacement of an existing pump, also its trailer mounted.
4. **What will the pump be used for?**
   - Over pumping a lift station in case of power failure, directing flow to the nearest manhole.
   - Managing large volumes of water from burst pipes and sewage spills.
   - Cleaning large tanks that hold at least 500,000 liters of water.
   - Overall, this pump will significantly assist with various tasks within the section.
5. **Are you the end user, buyer, contractor, or another party involved in the project?**
   - We are the end user, operating within the 48th Civil Engineer Squadron (CES) Water Fuel System Maintenance Shop, focusing on wastewater sewage management.
6. **What is your application or industry?**
   - Our work involves wastewater treatment, processing approximately 2.5 million liters of sewage daily.