Building #	Location	Make	Sprinkler Valve Location	Type	Date of Facility	Date System was installed
1102	NC3			Wet	1956	2023
1152	LG Supply	Gem	South East Corner of Build.	Wet	1956	1998
1106	Conference Center	Gem	Basement	Wet	1956	1998
1108	Admin Offices	FIRE PUMP	Basement	PUMP	1954	1998
1108	Admin Offices		3rd Floor Closet	**Dry**	1954	2019
1108	Admin Offices		Basement	Wet /**STD**	1954	2019
1109	Admin Offices		Basement	Wet/**STD**	1954	
1109	Admin Office		3rd Floor Coset	**Dry**	1954	
1109	Admin Office	FIRE PUMP	Basement	PUMP	1954	
1201	Steam Plant	Grinnell	Boiler Room	Wet	1954	2011
1201	Pump House	Grinnell	Pump House	Wet	1954	1986
1208	Munitions Mx	Viking	Bathroom	Wet	1954	1993
1240	Family Support		Rm 602 - Rear Mech Rm	Wet	1956	2016
1305	HQ ABG	Rasco	Mech Room	Wet/**STD**	1984	1984
1305	HQ ABG	FIRE PUMP	Mech Room	PUMP	1984	1984
1425	The Commons	Firematic	Basement	Wet	1954	2002
1427	VOQ	Victaulic	Basement	Wet	1954	2000
1435	SC Info.System & Computer	Victaulic	Mech Room	Wet	1959	2009
1435	SC Info.System & Computer	ANSUL NOVEC 1230	Server Room	**ANSUL**	1959	2012
1445	SF Warehouse	Victaulic	South East Corner of Build.	Wet	2006	2005
1510	Dorm	Victaulic	Stairwell	Wet/**STD**	1955	2001
1511	Dorm	Victaulic	Stairwell	Wet/**STD**	1955	2001
1531	Bowling center	Shotgun	Kitchen	Wet	1965	2016
1527	Dorm		Mech Room	**Dry**	2019	2019
1527	Dorm		Mech Room	Wet	2019	2019
1548	Fitness Center	Tyco 6”	Mech Room	Wet	1956	2006
1603	Chapel	Victaulic	Mech Room	Wet	1955	2016
1603	Chapel	Victaulic	Mech Room	**Dry/Nitro**	1955	2016
1604	PK/JA	Porter/Victaulic	Mech Room	Wet	2010	2009
1607	Elect. Rsch Eng	Victaulic	Basement Mech Room	Wet/**STD**	1955	2000
1608	Auto Hobby Shop	Reliable	Garage	Wet	1978	1999
1612	Elect Rsch Eng	Automatic	1st Floor Mech Room	Wet/**STD**	1981	1980
1614	Phase I	Rasco	Mech Room	Wet	1955	2001
1614	Phase II	Reliable	Loading Dock	Wet	1955	2001
1614	Phase 0	Reliable	Near Room 148	Wet	1955	2001
1618	Admin Office	Victaulic	Mech Room	Wet	1964	2014
1624	Elect. Rsch Eng	Firematic	Mech Room	Wet/**STD**	1987	2008
1630	Elect. Rsch Eng	Firematic	Mech Room	Wet/**STD**	1990	1987

STD = Standpipe

1642	Motor Pool	CSC	North Side (@pumps)	Wet	1955	1954
1642	Motor Pool	CSC	South Side	Wet	1955	1954
1646	DMATS	ANSUL IQ318/VESDA	1st floor/basement	**ANSUL**	1953	2012
1646	DMATS		Mech Room	Wet	1953	2018
1646	DMATS		Mech Room	Dry	1953	2018
1709	BX AAFES	Reliable	Zone B – Sprink Room	Wet	2002	2001
1712	Offices		Garage	Wet		2017
1712	Offices		Garage	**Dry**		2017
1725	Security Forces	Viking	Mech Room	Wet	1995	1994
1728	Education Center	Zasco 4”	Hall Closet	Wet	1955	1996
1813	BE Storage Shed	Viking	Mech Room	Wet	1952	2002
1813	BE Storage Shed	Viking	Mech Room	**Dry**	1952	2004
1827	CE Roads & Grounds	Victaulic	Mech Room	Wet	2007	2007
1993	Youth Center	Porter	Mech Room	Wet	1973	2004
1994	Child Care Center	Firematic	Mech Room	Wet	1994	1994
1999	After School Care	Reliable	Mech Room	**Dry**	1960	2001
Sagamore Hill	Sagamore Hill	IQ301 BFA, VESDA & INERGEN	Bldg 5	**ANSUL** **ANSUL**	1968 & 1990	2012