AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

1. CONTRACT ID CODE	PAGE	OF	PAGES
	1		3

2. AMENDMENT/MODIFICAITON NO.	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicble)
AMENDMENT NO. 0003	08/12/26		26-0438

6. ISSUED BY	CODE	7. ADMINISTERED BY (If other than Item 6)	CODE
NAVFAC Mid-Atlantic Resident Officer in Charge of Construction 1107A Birch Street Camp Lejeune, NC 28547-2521	N40085	See Item 6	

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)	(X)	9A. AMENDMENT OF SOLICIATION NO.
	X	N40085-26-R-9068
		9B. DATED (SEE ITEM 11) 07/22/26
		10A. MODIFICATION OF CONTRACT/ORDER NO.
		10B. DATED (SEE ITEM 11)
CODE / FACILITY CODE		

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended, ☒ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a)By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPIRATION DATA (If required)

13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE	
	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not, ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

26-0438, BUILDING BB6 ROOFING REPAIRS
Amendment 0003, Answers to Request for Information.

The time and date for receipt of proposals remains unchanged.

This amendment should be acknowledged when your proposal is submitted. Failure to acknowledge the amendment may constitute grounds for rejection of a proposal.

See Continuation Page(s)

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA (Signature of Contracting Officer)	16C. DATE SIGNED

CONTINUATION SHEET

QUESTION 1: Can the government supply a recent roof inspection?

ANSWER 1: Roof inspection is not available.

QUESTION 2: Is there anticipation that some work will need to be completed outside regular working hours?

ANSWER 2: If after-hours work becomes necessary, you must submit and obtain approval for a work request prior to commencing any work outside of regular hours.

QUESTION 3: Is the contractor going to be held to this specification? This is a roof project and this section deals with procedures for a contaminated site.

ANSWER 3: Yes, there could be contaminated or hazardous materials such as asbestos.

QUESTION 4: SOW states supervision can be a 3 hat. In the specs under 1.5.1.1 Duties it states the QCM may perform the superintendent duties. Please clarify.

ANSWER 4: All three duties can be performed by one person if qualified.

QUESTION 5: Please confirm if the separate QC Specialist listed are required for this project.

ANSWER 5: Yes, this will be the manufacturer QC.

QUESTION 6: It states that dumpsters be painted standard installation color. Please confirm if this is a requirement.

ANSWER 6: No, dumpsters do not have to be painted standard installation color.

QUESTION 7: Can we use cold process on the low slope because there is a wood deck below?

ANSWER 7: Cold applied process will not be allowed.

QUESTION 8: Can we clarify the metal detail at the rake wall to valley transition on the standing seam metal roof?

ANSWER 8: Provide flashing as per roof manufacturer standard detail/recommendations.

QUESTION 9: Can we use a drip edge that transitions into the existing gutter? or are we require to remove the gutter and replace the facia?

ANSWER 9: Remove gutter, downspout and fascia. Replace to match existing size/style.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.