22 ATKS UPS BATTERY REPLACEMENT

Background:

The 22d Attack Squadron requires the purchase and replacement of 120 Uninterrupted Power Supply (UPS) batteries with 120 new "C&D UPS12-495PLP" batteries, with new connect, and factionally tested (all batteries, necessary tools, shop supplies, and labor will be provided by the contracted company/workers). Connect and test function of overall system after installation of batteries in building 1057, Creech AFB, NV. Members of the 22 ATKS will provide and facilitate full accesses to necessary work areas M-F, 0800-1600 (not including federal holidays).

Scope:

The contractor shall furnish and install all required components, accessories, and user documentation in accordance with the specifications below:

- UPS Batteries - C&D UPS12-495PLP