AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

BPA NO.	1. CONTRACT ID CODE	PAGE OF PAGES

2. AMENDMENT/MODIFICATION NUMBER	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQ. NUMBER	5. PROJECT NUMBER (if applicable)
0002	08-12-2026	36C263-26-AP-2830	656-12-222

6. ISSUED BY CODE 36C263

DEPARTMENT OF VETERANS AFFAIRS
NETWORK CONTRACTING OFFICE 23
Dwayne Brauch, Contracting Officer
316 ROBERT STREET N, SUITE 506
SAINT PAUL MN 55101

7. ADMINISTERED BY (If other than Item 6) CODE

DEPARTMENT OF VETERANS AFFAIRS
NETWORK CONTRACTING OFFICE 23

316 ROBERT STREET N, SUITE 506
SAINT PAUL MN 55101

8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code)

To all Offerors/Bidders

CODE FACILITY CODE

(X)	
	9A. AMENDMENT OF SOLICITATION NUMBER 36C26326B0035
X	9B. DATED (SEE ITEM 11) 07-15-2026
☐	10A. MODIFICATION OF CONTRACT/ORDER NUMBER
	10B. DATED (SEE ITEM 13)

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

[X] The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers [X] is extended, [ ] is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified. ** HOUR & DATE for Receipt of Offers is EXTENDED to: 08-17-2026 10 CDT

12. ACCOUNTING AND APPROPRIATION DATA (If required) 656-3660162-3218-854200 3220 23NR5WC10

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE	
☐	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
☐	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
☐	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
☐	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor [ ] is not, [ ] is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

The purpose of this Amendment is to:
1. Publish Questions and Answers see attached summary of changes.

All other terms and conditions remain the same.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
		Eric Reis VA-VHA-RPOC-2023-0101 Contracting Offficer	
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA (Signature of Contracting Officer)	16C. DATE SIGNED

Summary of Changes

1. Building 9 window marks W7 are they the transoms over the doors, or do we need to include the doors

as well in our bid with the transoms.

The drawings break down the door and transom unit. It is our expectation that both the doors and transoms be replaced

2. in 085201 spec section, paragraph 1.09 section B, item 2 -b-2 calls for a 12# water. Residential hung

windows have a max of 8# then you would take 2/3 of that. Please confirm the correct pressure.

The windows being installed are residential style units. The windows shall be tested to meet the window manufacturer's testing parameters.

3. Panning system (aluminum) on the details, is this to be extruded or sheet aluminum that can be bent.

Not coil stock.

Thinner gauge coil stock will not be accepted. Sheet aluminum formed to fit each opening is acceptable.

4. Just got another comment from the manufacturers, they cannot supply the glass make up as specified in the 088000 spec.

Glazing as specified in section 085000 is acceptable.

2.6 INSULATING GLASS UNITS

A. Provide factory fabricated, hermetically sealed glass unit consisting of two panes of glass separated by a dehydrated air space and comply with ASTM E2190.

B. Assemble units using glass types specified:

C. Sealed Edge Units (SEU):

1. Insulating Glass Unit Makeup
   a. Outboard Lite
      1. Glass type: Clear with low-E coating on #2 surface.
      2. Nominal Thickness: 6 mm (1/4 inch).
   b. Spacer
      1. Nominal Thickness: 12 mm (1/2 inch).
      2. Gas Fill: 90% Argon
   c. Inboard Lite
      1. Glass Type: Clear **laminated** glass.
      2. Nominal Thickness: 8 mm (5/16 inch).

They are pricing the glass make up that is in the 085000 section

A. Glazing: Double glazed, clear, Low-E coated, argon filled, with glass thicknesses as recommended by manufacturer for specified wind conditions.