15) Are outage windows limited to specific dates or operational periods?

No specific limitations at this time. Mondays are preferred.

16) Can multiple transformers be de-energized and maintained during one outage event?

Yes.

17) Can all of the work be completed during a single mobilization?

With the proper coordination this may be possible however this will depend on timing of outages/mission requirements.

18) Is escorting required for contractor personnel?

Contractor badging will be required for the awardee, this will allow unescorted work within the base however 3 transformers are located within a restricted area which will require escorts. This work will be coordinated with the Government.

19) Will the government provide switching support during outages?

No, the contractor will be responsible for anything beyond coordination/access.

20) Does NETA IV apply to the field phase or the execution phase? Does the on-site work require the presence of NETA IV?

All contractors performing work on medium voltage equipment shall hold the proper qualifications throughout the period of performance. Proof of said qualifications shall be provided to the Contracting Officer with your quote.

21) Please confirm whether a badge registration process is required for site access. If required, please provide the estimated time needed to complete registration and obtain an entry badge.

Yes, badge registration is required. Estimated time for obtaining a badge is one week from the time the badge application is submitted.

22) We have previously performed work at Buckingham Airport and have completed the badge registration process. Based on our existing credentials, will personnel be exempt from any badge registration requirements for accessing the project sites, or will new registrations be required?

There will be no exemptions. Badge registrations will be required for all personnel.