AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

1. CONTRACT ID CODE	PAGE	OF	PAGES
J	1		2

2. AMENDMENT/MODIFICATION NUMBER	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQUISITION NUMBER	5. PROJECT NUMBER *(If applicable)*
0001	05 AUG 2026		

6. ISSUED BY	CODE	7. ADMINISTERED BY *(If other than Item 6)*	CODE
W2SD ENDIST NEW ENGLAND KO CONTRACTING DIVISION, 696 VIRGINIA ROAD CONCORD, MA 01742-2751 UNITED STATES ALICIA LACROSSE, EMAIL: ALICIA.N.LACROSSE@USACE.ARMY.MIL TELEPHONE: 978-318-8902	W912WJ	SCD: PAS:	

8. NAME AND ADDRESS OF CONTRACTOR *(Number, street, county, State and ZIP Code)*	(X)	9A. AMENDMENT OF SOLICITATION NUMBER
	☒	W912WJ26QA140
		9B. DATED *(SEE ITEM 11)* 23 JUL 2026
	☐	10A. MODIFICATION OF CONTRACT/ORDER NUMBER
		10B. DATED *(SEE ITEM 13)*
CODE / FACILITY CODE		

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended. ☒ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA *(If required)*

SEE SECTION G - CONTRACT ADMINISTRATION DATA

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NUMBER AS DESCRIBED IN ITEM 14.

CHECK ONE	
☐	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: *(Specify authority)* THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NUMBER IN ITEM 10A.
☐	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES *(such as changes in paying office, appropriation data, etc.)* SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
☐	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
☐	D. OTHER *(Specify type of modification and authority)*

E. IMPORTANT: Contractor ☐ is not ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (*Organized by UCF section headings, including solicitation/contract subject matter where feasible.)*

Amendment is necessary to provide a response to a question from industry.

Solicitation closing remains August 6, 2026 at 5:00 PM Eastern.

All other terms and conditions remain unchanged.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER *(Type or print)*		16A. NAME AND TITLE OF CONTRACTING OFFICER *(Type or print)*	
		JENNIFER SAMELA	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
(Signature of person authorized to sign)		*(Signature of Contracting Officer)*	05 AUG 2026

Previous edition unusable

STANDARD FORM 30 (REV. 11/2016)
Prescribed by GSA FAR (48 CFR) 53.243

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

Section A - Solicitation/Contract Form

The following changes have been made:

Miscellaneous text in this section has been added to:

REQUEST FOR INFORMATION:

QUESTION 1: Is it required for the Culverts to be cleaned out Completely through and through beginning to start? Or at the door way entrances? What is the diameter of each opening?

RESPONSE 1: Yes, the culverts need to be cleaned out completely from beginning to end. The interior of the concrete box culvert labeled as Old Route 109 is 8'-0" high by 12'-2" wide perpendicular between the walls. The culvert length along its centerline of the box is 21'-0" as measured along the centerline of the road. The other box culvert at the cul-de-sac is Roughly 6' by 4' and is 20' long.