



Addendum #04

IFB No. 130525 – Building 632
Camp San Luis Obispo - San Luis Obispo, CA
8/6/2026 at 5:00 PM

08/18/2026

Please review the following addendum to IFB No. 130525.

1. Attachment 1 – SOW Rev 04
2. The bid due date remains unchanged.

Please note that no verbal information given will be binding upon the State unless such information is issued in writing as an official addendum.

Robert Hawkins
Contracting Administrator

MILITARY DEPARTMENT
OFFICE OF THE ADJUTANT GENERAL
10601 Bear Hollow Drive
Rancho Cordova, California 95670
STATE OF CALIFORNIA



Gavin Newsom, Governor

Attachment 1

SOW Rev 04



Addendum #04

IFB No. 130525 – Building 632
Camp San Luis Obispo - San Luis Obispo, CA
8/6/2026 at 5:00 PM

08/18/2026

CAMP SAN LUIS OBISPO BLDG. 632 ROOF REPLACEMENT BID#130525

1. Can the QC Manager and Superintendent be the same person? Can the Qc Manager and Safety Officer be the same person?
(It is understood and accepted that one person cannot be all three. QC Manager, Safety Person and Superintendent)
 - a. According to the specifications the QC manager may perform the duties of the safety officer. Superintendent cannot be QC Manager.
2. Please find attached a substitution request for the roof system materials. We are submitting Johns Manville as an equal to the Garland roof system that is specified.
 - a. The PVC membrane in the specifications is an ASTM 6755 KEE membrane, and the Johns Manville is not equal.
